

# Investment Grade Energy Audit in Government Buildings in Kerala



Energy Management Centre-Kerala

Dept. of Power, Govt. of Kerala

Sreekrishna Nagar

Sreekariyam

Thiruvananthapuram 695017

June 2010

## About the Report

Globally it is understood that the building sector accounts to 40 % of the total energy use today. According to World Business Council of Sustainable Development, energy efficiency in buildings and appliances alone can reduce carbon emission by 715 million tons globally which would be 27 % of the projected increase in GHG emissions to date.

The Situational Analysis conducted by the Bureau of Energy Efficiency indicated a savings potential of 137 MW in the Government Buildings. Further, studies in several office buildings, hotels and hospitals indicated an energy savings potential of 20-50 % in end uses such as lighting, ventilation and cooling, building services operation etc. This represents a vast yet untapped, savings potential attributable mainly to lack of an effective delivery mechanism for energy efficiency with tangible financial benefit to the individual as well as the nation.

Energy Management Center Kerala is contributing its bit to the national as well as global need for better efficiency in building sector.

Twenty Two Buildings were identified to be part of the Investment Grade Energy Audit (IGEA) under the nationwide programme of the Bureau of Energy Efficiency, MoP, Govt. of India. The Energy Audits were conducted during the period 2008-09.

The major savings identified were in lighting, air conditioning and electrical distribution systems. It could be identified that there are several low hanging fruits such as retrofitting with T5 lamps, replacement of incandescent lamps, retrofitting with electronic regulators, providing variable frequency drives, power factor improvement etc...

The total savings to be achieved in all these 22 buildings are nearly 18 % of the present energy consumption and a pay back of less than 1.5 years is envisaged for the energy saving project investment.

Along with the IGEA programme, the Bureau of Energy Efficiency has already started the Star Labeling Programme for commercial buildings. Energy Conservation Building Code is also introduced in the country and various States are implementing the same in their respective States. Kerala is also in the consultative process for the implementation of the same.

The report contains the summary of energy savings identified by the IGEA as well as the highlights of the consultative meeting held on November 14<sup>th</sup> at Mascot Hotel, Trivandrum

## Contents

| SN       | Topic  | Page Number |
|----------|--|-------------|
|          | <b>Abbreviations</b>   |             |
| <b>1</b> | <b>About Energy Management Centre-Kerala</b>                   | 4           |
| <b>2</b> | <b>IGEA Programme</b>  | 5           |
| <b>3</b> | <b>Scope of IGEA</b>   | 7           |
| <b>4</b> | <b>Consolidated energy savings Identified</b>                  | 10          |
| <b>5</b> | <b>Energy Savings Summary - Building Wise</b>                  |             |
| 5.1      | Kerala Legislature Complex, Thiruvananthapuram                 | 13          |
| 5.2      | Kerala Secretariat Complex, Thiruvananthapuram                 | 15          |
| 5.3      | Government Medical College Hospital, Thiruvananthapuram        | 17          |
| 5.4      | Regional Cancer Centre, Thiruvananthapuram                     | 19          |
| 5.5      | Mascot Hotel, KTDC, Thiruvananthapuram                         | 21          |
| 5.6      | Vydyuthi Bhawan , Thiruvananthapuram                           | 23          |
| 5.7      | State Bank of Travancore , Thiruvananthapuram                  | 25          |
| 5.8      | Shaktan Thampuran Arcade, Thrissur                             | 27          |
| 5.9      | Mail Business Centre, Thiruvananthapuram                       | 28          |
| 5.10     | The Kerala State Planning Board, Thiruvananthapuram            | 29          |
| 5.11     | General Post Office Building, Thiruvananthapuram               | 31          |
| 5.12     | Rajiv Gandhi Centre for Biotechnology, Thiruvananthapuram      | 34          |
| 5.13     | BSNL–The Panampilly Nagar Telephone Exchange, Ernakulam        | 36          |
| 5.14     | Telecom Exchange Building, Medical College, Thiruvananthapuram | 39          |
| 5.15     | Vikas Bhawan, Thiruvananthapuram                               | 41          |
| 5.16     | Civil Station, Kozhikode                                       | 42          |
| 5.17     | Government Medical College, Kozhikode                          | 45          |
| 5.18     | Finance Towers, Kerala Financial Corporation, Ernakulam        | 46          |
| 5.19     | College of Engineering, Thiruvananthapuram                     | 47          |
| 5.20     | Civil Station, Thrissur  | 48          |
| 5.21     | Civil Station, Ernakulam                                       | 49          |
| 5.22     | High Court Building, Ernakulam                                 | 51          |
| <b>6</b> | <b>IGEA Consultative Meeting-Highlight</b>                     | 54          |
| <b>7</b> | <b>Conclusion</b>  | 59          |

| <b>Sl. No.</b> | <b>Abbreviation</b> | <b>Expansion</b>                                     |
|----------------|---------------------|--|
| 1              | V                   | volt   |
| 2              | A                   | ampere   |
| 3              | kW                  | kilo watt  |
| 4              | kWh                 | kilo watt hour                                       |
| 5              | P F                 | Power Factor   |
| 6              | kVA                 | kilo volt ampere                                     |
| 7              | kVA <sub>r</sub>    | kilo volt ampere reactive                            |
| 8              | EER                 | Energy Efficiency Ratio                              |
| 9              | THD                 | Total Harmonic Distortion                            |
| 10             | HT                  | High Tension   |
| 11             | LT                  | Low Tension  |
| 12             | DSM                 | Demand Side Management                               |
| 13             | AHU                 | Air Handling Unit                                    |
| 14             | HVAC                | Heating, Ventilation & Air-Conditioning              |
| 15             | FTL                 | Fluorescent Tubular Lamps                            |
| 16             | CFL                 | Compact Fluorescent Lamp                             |
| 17             | DG                  | Diesel Generator                                     |
| 18             | ROI                 | Return On Investment                                 |
| 19             | IRR                 | Internal Rate of Return                              |
| 20             | IGEA                | Investment Grade Energy Audit                        |
| 21             | ESCO                | Energy Service Company                               |
| 22             | ENCON               | Energy Conservation                                  |
| 23             | BSNL                | Bharat Sanchar Nigam Limited                         |
| 24             | UNIDO               | United Nations Industrial Development Organization   |
| 25             | PWD                 | Public Works Department                              |
| 26             | BEE                 | Bureau of Energy Efficiency                          |
| 27             | EMC                 | Energy Management Centre                             |
| 28             | KSEB                | Kerala State Electricity Board                       |
| 29             | SDA                 | State Designated Agency                              |
| 30             | KSPC                | Kerala State Productivity Council                    |
| 31             | FICCI               | Federation of Indian Chambers of Commerce & Industry |

## 1. About Energy Management Centre-Kerala

**Energy Management Centre-Kerala (EMC)** was established in February 1996 as an autonomous organization under the Department of Power, Government of Kerala. EMC has got a functional framework devoted to comprehensive and multi-disciplinary institutional objectives and orientation encompassing all aspects of energy, with a focus on energy-environment-development interactions.



The guiding philosophy and school of thought of EMC is "achieving sustainable development through enhancing total energy efficiency and application of renewable energy and environment friendly energy systems in all sectors of the economy". To realize the above goals, EMC is adopting a multi-faceted institutional and functional strategy.

Established with an aim to remould and instrumentalise energy sector as a catalyst in promoting a development process which is econo-ecologically sustainable, Energy Management Centre has been undertaking its role successfully for the past 14 years.

The Centre is also promoting Small Hydro Power developments in the State. The United Nations Industrial Development Organization (UNIDO) opened its first Regional Centre for Small Hydro Power in Energy Management Centre on 4 April 2003.

Government of Kerala vide notification number, 2450 (S R O No.1212/2003) designated Energy Management Centre to enforce the Energy Conservation Act 2001 in the State. The Bureau of Energy Efficiency (BEE), MoP, Govt. of India was undertaking the implementation of the Energy Conservation Act 2001 in the country and EMC is closely working with BEE in this regards availing support, guidance and assistance.

## 2. Investment Grade Energy Audit Programme

EMC has taken up Investment Grade Energy audit of twenty two large Government buildings under the aegis of the nationwide programme of “Investment Grade Energy Audit (IGEA) of 500 Government Buildings” of the Bureau of Energy Efficiency, Ministry of Power, Government of India.

EMC has identified 22 buildings which are owned by the Government or Public Undertakings or autonomous bodies or local bodies. The BEE listed Energy Service Companies and Energy Audit Consultants were invited to bid for the IGEA of identified buildings.

The list of buildings and Consultants/ Energy Audit Firms is given below.

| SI No | Building   | Audit Firm   |
|-------|--|--|
| 1     | Kerala Legislature Complex, Thiruvananthapuram           | Kerala State Productivity Council, Ernakulam                       |
| 2     | Kerala Secretariat Complex, Thiruvananthapuram           | Kerala State Productivity Council, Ernakulam                       |
| 3     | Government Medical College Hospital, Thiruvananthapuram  | Energetic Consulting (P) Ltd, Mumbai                               |
| 4     | Regional Cancer Centre, Thiruvananthapuram               | Federation of Indian Chamber of Commerce and Industries, New Delhi |
| 5     | Mascot Hotel, KTDC, Thiruvananthapuram                   | Federation of Indian Chamber of Commerce and Industries, New Delhi |
| 6     | Vydyuthi Bhawan , Thiruvananthapuram                     | Federation of Indian Chamber of Commerce and Industries, New Delhi |
| 7     | State Bank of Travancore , Thiruvananthapuram            | BSNL, Office of Chief Engineer (Electrical), Thiruvananthapuram    |
| 8     | Shaktan Thampuram Arcade, Thrissur                       | Federation of Indian Chamber of Commerce and Industries, New Delhi |
| 9     | Mail Business Centre, Thiruvananthapuram                 | Federation of Indian Chamber of Commerce and Industries, New Delhi |
| 10    | The Kerala State Planning Board, Thiruvananthapuram      | BSNL, Office of Chief Engineer (Electrical), Thiruvananthapuram    |
| 11    | General Post Office Building, Thiruvananthapuram         | BSNL, Office of Chief Engineer (Electrical), Thiruvananthapuram    |
| 12    | Rajiv Gandhi Centre of Biotechnology, Thiruvananthapuram | Federation of Indian Chamber of Commerce and Industries, New Delhi |
| 13    | BSNL–The Panampilly Nagar Telephone Exchange, Ernakulam  | BSNL, Office of Chief Engineer (Electrical), Thiruvananthapuram    |

| <b>SI No</b> | <b>Building Name</b>   | <b>Audit Firm</b>  |
|--------------|--|--|
| 14           | Telecom Exchange Building, Medical College, Thiruvananthapuram | BSNL, Office of Chief Engineer (Electrical), Thiruvananthapuram    |
| 15           | Vikas Bhawan, Thiruvananthapuram                               | Federation of Indian Chamber of Commerce and Industries, New Delhi |
| 16           | Civil Station, Kozhikode                                       | Eaga Energy India Pvt. Ltd., Kolkata                               |
| 17           | Government Medical College, Kozhikode                          | Eaga Energy India Pvt. Ltd., Kolkata                               |
| 18           | Finance Towers, Kerala Financial Corporation, Ernakulam        | Eaga Energy India Pvt. Ltd., Kolkata                               |
| 19           | College of Engineering, Thiruvananthapuram                     | Eaga Energy India Pvt. Ltd., Kolkata                               |
| 20           | Civil Station, Thrissur  | Eaga Energy India Pvt. Ltd., Kolkata                               |
| 21           | Civil Station, Ernakulam                                       | Federation of Indian Chamber of Commerce and Industries, New Delhi |
| 22           | High Court Building, Ernakulam                                 | BSNL, Office of Chief Engineer (Electrical), Thiruvananthapuram    |

### 3. Scope of Investment Grade Energy Audit

The scope of the work includes a detail study for energy conservation options of various energy sources like Electricity and Fuel oil in the building and recommendation with detailed techno economic and cost benefits.

The broad scope of the study was as per the following.

a) Review of present electricity & fuel consumption and utilization practices and estimation of energy consumption in various load centers like Lighting, Air-Conditioning, Water Pumping and end user applications.

#### b) Electrical Distribution System

- Review of present electrical distribution like Single Line Diagram (SLD), transformer loading, cable loading, normal & emergency loads, electricity distribution in various areas / floors etc.
- Study of Reactive Power Management and option for power factor improvement.
- Study of power quality issues like Harmonics, current unbalance, voltage unbalance etc,
- Exploring the Energy Conservation Opportunities (ENCON)

#### c) Lighting System

- Review of present lighting system, lighting inventories etc.
- Estimation of lighting load at various locations like different floors, outside (campus) light, pump house and other important locations.
- Detail lux level survey at various locations and comparison with acceptable standards.
- Study of present lighting control system and recommend for improvement.
- Analysis of lighting performance indices like Lux/m<sup>2</sup>, lux/watt, lux/watt/m<sup>2</sup> and comparison with norms of high rise buildings.
- Exploring the Energy Conservation Options (ENCON) in lighting system.

#### d) Heating, Ventilation & Air-Conditioning (HVAC) System

- Review of present HVAC system like central AC, window AC, split AC; package AC, Water Coolers, and Air Heaters etc.
- Performance assessment of window AC, Split AC and Package AC system.
- Performance Assessment of Chillers, Cooling Towers, Air Handling Units (AHUs) and cold insulation system of central AC.
- Analysis of HVAC Performance like estimation of Energy Efficiency Ratio (EER i.e. KW/TR), Specific Energy Consumption (SEC) of Chilled Water Pumps, Condenser Water Pumps, AHUs etc and comparison of the operating data with the design data.
- Exploring the Energy Conservation Options (ENCON) in HVAC system.



**e) Diesel Generator (DG) Sets**

- Review of DG set operation
- Performance Assessment of DG sets in terms of Specific Fuel Consumption (SFC i.e. KWH/Liter).
- Exploring the Energy Conservation Options (ENCON) in lighting system.
- Exploring the Energy Conservation Options (ENCON) in DG Sets.

**f) Water Pumping System**

- Review of water pumping, storage and distribution systems.
- Performance assessment of all major water pumps i.e. power consumption vs. flow delivered, estimation of pump efficiency etc.
- Exploring the Energy Conservation Options (ENCON) in Water Pumping System.

**g) Thermic Fluid Heaters / Boilers**

- Performance assessment of hot water generators or thermic fluid heaters like estimation of efficiency etc.
- Exploring the ENCON options in this systems

**h) Motor Load Survey**

- Conducting the motor load survey of all drives to estimate the % loading.
- Exploring the ENCON options in electric drive system.

**i) Energy Monitoring & Accounting System**

- Detail review of present energy monitoring & accounting system in terms of metering, record keeping, data logging, periodic performance analysis etc. b. Recommend for effective energy monitoring & accounting system.

**j) Others**

- Review of present maintenance practice, Replacement policies and building safety practices as applicable to high rising buildings and recommend for improvements.
- Cost-Benefit Analysis of each ENCON options indicating simple payback period, return on investment (ROI), internal rate of return (IRR).
- Preparation of Detail Project Report and submission of the same to SDA/Building owner/BEE.

## **DELIVERABLES IN THE DETAIL PROJECT REPORT (DPR)**


- Methodology adopted for the study.
- Present energy scenario of the building.
- Detail analysis of the data obtained through field visits, trial measurements by portable gadgets, discussion with concerned personnel etc.
- Recommendations for energy saving options in all possible areas with cost-benefit analysis.
- Technical Specifications for any retrofit options,
- List of suppliers / manufacturers of energy efficient technologies

#### 4. Consolidated savings data of all the Identified buildings

| SN | Building   | Electrical Energy Consumption kWh/annum | Savings in kWh/annum | Savings in lakh INR/annum | Investment in lakh INR/annum |
|----|--|---|----------------------|---------------------------|------------------------------|
| 1  | Kerala Legislature Complex, Thiruvananthapuram                 | 2,133,399                               | 3,43,889             | 49.59                     | 31.49                        |
| 2  | Kerala Secretariat Complex, Thiruvananthapuram                 | 1,661,594                               | 4,44,061             | 43.64                     | 19.12                        |
| 3  | Government Medical College Hospital, Thiruvananthapuram        | 3,349,263                               | 7,84,413             | 39.22                     | 59.69                        |
| 4  | Regional Cancer Centre, Thiruvananthapuram                     | 3,000,000                               | 8,67,000             | 40.91                     | 59.03                        |
| 5  | Mascot Hotel, KTDC, Thiruvananthapuram                         | 1,656,000                               | 1,86,152             | 24.92                     | 18.43                        |
| 6  | Vydyuthi Bhawan , Thiruvananthapuram                           | 600,000                                 | 1,82,844             | 9.16                      | 23                           |
| 7  | State Bank of Travancore , Thiruvananthapuram                  | 998,736                                 | 85,555               | 16.02                     | 16.67                        |
| 8  | Shaktan Thampuran Arcade, Thrissur                             | 9,166                                   | 9,166                |                           |                              |
| 9  | Mail Business Centre, Thiruvananthapuram                       | 93,336                                  | 20,183               | 1.00                      | 1.99                         |
| 10 | The Kerala State Planning Board, Thiruvananthapuram            | 86,880                                  | 49,823               | 4.26                      | 12.85                        |
| 11 | General Post Office Building , Thiruvananthapuram              | 173,804                                 | 89,108               | 6.53                      | 10.3                         |
| 12 | Rajiv Gandhi Centre of Biotechnology, Thiruvananthapuram       | 16,62,000                               | 2,64,130             | 13.13                     | 13.55                        |
| 13 | BSNL–The Panampilly Nagar Telephone Exchange, Ernakulam        | 28,40,432                               | 3,14,791             | 15.11                     | 12.85                        |
| 14 | Telecom Exchange Building, Medical College, Thiruvananthapuram | 28,14,491                               | 1,99,051             | 8.51                      | 10.65                        |
| 15 | Vikas Bhawan, Thiruvananthapuram                               | 240,000                                 | 1,39,792             | 11.07                     | 17.5                         |
| 16 | Civil Station, Kozhikode                                       | 459,445                                 | 1,40,732             | 18.18                     | 30.46                        |
| 17 | Government Medical College, Kozhikode                          | 5,264,400                               | 6,36,382             | 32                        | 28                           |
| 18 | Finance Towers, Kerala Financial Corporation, Ernakulam        | 848,917                                 | 28,096               | 1.53                      | 2.75                         |
| 19 | College of Engineering, Thiruvananthapuram                     | 781,384                                 | 2,21,900             | 13.81                     | 21.06                        |
| 20 | Civil Station, Thrissur  | 145,971                                 | 40,677               | 2.24                      | 2.76                         |
| 21 | Civil Station, Ernakulam                                       | 322,800                                 | 61,512               | 4.14                      | 8.27                         |
| 22 | High Court Building, Ernakulam                                 | 1,607,739                               | 2,28,865             | 12.59                     | 48.28                        |
|    | <b>Total</b>   | <b>32,098,587</b>                       | <b>53,38,122</b>     | <b>367.5</b>              | <b>449.15</b>                |

**System Wise Consolidated savings in kWh or Units**


**Savings in kWh**



\*Demand savings not included(Demand savings was calculated as 906kVA).

**System Wise Consolidated savings in INR**

**Savings in INR**



\*\* Demand savings included.

## 5. Building Wise

### Energy Savings Summary

## 5.1. Kerala Legislature Complex, Thiruvananthapuram

Audited by: KSPC, Ernakulam

In 1956, the State of Kerala was formed on linguistic basis, merging Travancore, Cochin and Malabar regions. The first general election in the Kerala State was held in February-March, 1957. The first Kerala Legislative Assembly was formed on March 1, 1957. The Assembly had 127 members including a nominated member. Presently the assembly consists of 141 elected members.

The State Assembly is known as Niyama Sabha and is housed in New Legislature Complex. This 10 storied complex is one of the largest complexes in India. The Central Hall is described as most elegant and majestic hall with ornamental TeakWood-Rosewood paneling.

The consolidated statement of power consumption details for the last year is as follows:

| YEAR    | Average Maximum Demand (kVA) | Power Consumption (kWh) |                 |
|---------|------------------------------|-------------------------|-----------------|
|         |                              | Annual                  | Monthly Average |
| 2007-08 | 450                          | 2552900                 | 212742          |

### Executive Summary of Savings Identified

| Sl. No | Energy Conservation Opportunities  | Annual savings |                   | Investment (in Rupees) | Payback period (Months) |
|--------|--|----------------|-------------------|------------------------|-------------------------|
|        |  | kVA/kWh/L trs. | Value (in Rupees) |                        |                         |
| 1      | Connect 893 kVAR capacitors to improve the average system power factor from 0.75 to unity.                                     | 360 kVA        | 3,060,698         | 1,071,000              | 4                       |
| 2      | Distribute the entire load of the complex through a single transformer of 1600 kVA during normal working days.                 | 29386 kWh      | 162,209           | Not Estimated          |                         |
| 3      | Provide Variable Frequency Drives for the major AHU's, Chilled Water Pumps and Cooling Tower Fans in the Assembly Hall Complex | 52110 kWh      | 287,647           | 906,250                | 38                      |
| 4      | Provide Variable Frequency Drives for the AHU's in the Administration Building   | 29709 kWh      | 163,994           | 312,500                | 23                      |
| 5      | Replace Ordinary Regulators By Electronic Regulators In Ceiling Fans   | 17100 kWh      | 94,392            | 47,500                 | 6                       |
| 6      | Savings by Avoiding Fluorescent tube fittings or by Converting Double Tube fittings to Single tube fittings at Window Side     | 67050 kWh      | 370,116           | Nil                    |                         |
| 7      | Savings By Replacing 250 W Sodium Vapour Lamps with T5 Lamps With Ballasts.  | 29004 kWh      | 160,104           | 129,000                | 10                      |
| 8      | Install Energy Saver For Yard Lighting at the Assembly Complex   | 9316 kWh       | 51,424            | 75,000                 | 18                      |
| 9      | Replace 40W tubes with ordinary Choke by T5 Lamps  | 96954 kWh      | 535,186           | 577,600                | 13                      |
| 10     | Saving by Replacing Incandescent Lamps provided in the Assembly Hall Galleries with CFL's                                      | 13260 kWh      | 73,195            | 30,600                 | 5                       |

|    |   |              |           |           |   |
|----|---|--------------|-----------|-----------|---|
| 11 | Provide optimum sized motor with soft starter for the 580 T chillers so that the low loading, high demand rise and the high current due to low pf can be avoided.                                 |              |           |           |   |
| 12 | Increase the evaporator chilled water temperature setting in the chiller from 6.5°C to 10°C to get a 10% reduction in power consumption in the chiller units.                                     |              |           |           |   |
| 13 | Provide Two way Valve system in the chilled water line near the AHU's to control the flow of chilled water and thereby reducing the power consumption of chilled water pumping system.            |              |           |           |   |
| 14 | Replace the present motors of the AHU's, Chilled water pumps and Cooling Tower fans with optimum sized Energy Efficient motors to have better power factor as well as better operating efficiency |              |           |           |   |
| 15 | Provide temperature sensors for the cooling towers to avoid the operation of cooling tower fans after achieving the required temperature of the cooling water.                                    |              |           |           |   |
| 16 | Ensure proper closing/ Insulation of doors and windows in the air conditioned area to avoid additional heat load to the air conditioner.  |              |           |           |   |
| 17 | Set the air conditioning area temperature within a range of 24°C to 26°C to have better human comfort and hence to save power.  |              |           |           |   |
| 18 | Avoid the usage of lights during daytime where enough natural lighting is available.  |              |           |           |   |
| 19 | Remove the tree branches and the dust particles covering the Street Light fittings to ensure proper distribution of luminous intensity.   |              |           |           |   |
| 20 | It is strongly recommended to switch off lights, fans, A/c's as and when the person leaves the place as well as after office hours  |              |           |           |   |
| 21 | Provide individual controls for lights to avoid operation unwanted of lights.   |              |           |           |   |
| 22 | May Replace the existing CRT monitors of the computers with LCD monitors as the power consumption will be reduced by 70%.   |              |           |           |   |
|    | Total Savings   | 3,43,889 kWh | 49,58,965 | 31,49,450 | 8 |

A total amount of assured savings of Rs 49, 58,965/- with an estimated investment of Rs 31, 49,450/-. If we consider a simple pay back for the total investment we can understand that it is less than a year.

## 5.2. Kerala Secretariat Complex, Thiruvananthapuram

Audited by: KSPC, Ernakulam

### Executive Summary of Savings Identified

| Sl. No. | Energy Conservation Opportunities  | Annual savings |                   | Investment (in Rupees) | Payback period Months |
|---------|--|----------------|-------------------|------------------------|-----------------------|
|         |  | kVA/kWh/Ltrs.  | Value (in Rupees) |                        |                       |
| 1       | Repair the faulty capacitors to improve the average system power factor from 0.98 to 0.99.(Consumer No: 29/2973, Old Connection)                                     | 21 kVA         | 1,35,925          | 99,000                 | 9                     |
| 2       | Add 178 kVAR capacitors to improve the average system power factor from 0.66 to unity.(Consumer No: 6/4470, New Connection)  | Nil            | 4,23,182          | 99,000                 | 3                     |
| 3       | Add 40 kVAR capacitors to improve the average system power factor from 0.76 to unity (29/3427, Annexe Connection)  | Nil            | 98,984            | 48,000                 | 6                     |
| 4       | Reduce the contract demand of Consumer No: 6/4470 (New Connection) from 730 kVA to 240 kVA after improving the power factor  | 364 kVA        | 13,07,912         | Not Estimated          |                       |
| 5       | Reduce the contract demand of Consumer No: 29/3427(Annexe Connection) from 200 kVA to 140 kVA after improving the power factor                                       | 56 kVA         | 1,62,069          | Not Estimated          |                       |
| 6       | Isolate one of the 350 kVA transformer of the Consumer No: 29/2973 (Old Connection)in the HT side itself so that the core loss can be avoided during no Load Periods | 4,848 kWh      | 22,010            | Nil                    |                       |
| 7       | Replace Ordinary Regulators By Electronic Regulators In Ceiling Fans (Consumer No: 29/2973, Old Connection)  | 36,576 kWh     | 1,66,055          | 1,01,600               |                       |
| 8       | Replace Ordinary Regulators By Electronic Regulators In Ceiling Fans (Consumer No: 29/3427, Annexe Connection)   | 11,160 kWh     | 71,201            | 31,000                 |                       |
| 9       | Savings by Avoiding Fluorescent tube fittings or by Converting Double Tube fittings to Single tube fittings at Window Side (Consumer No: 29/2973)                    | 92,928 kWh     | 4,21,893          | Nil                    |                       |
| 10      | Savings by Avoiding Fluorescent tube fittings or by Converting Double Tube fittings to Single tube fittings at Window Side (Consumer No: 29/3427)                    | 45,804 kWh     | 2,92,230          | Nil                    |                       |
| 11      | Install Energy Saver For Yard Lighting at the Secretariat Complex (Consumer No: 29/2973).  | 6,570 kWh      | 29,828            | 30,000                 |                       |
| 12      | Replace 40W tubes with ordinary Choke by T5 Lamps (Consumer No: 29/2973, Old Connection)   | 1,83,805 kWh   | 8,34,475          | 1,123,600              |                       |
| 13      | Replace 40W tubes with ordinary Choke by T5 Lamps (Consumer No: 29/3427, Annexe Connection)  | 62,370 kWh     | 3,97,921          | 3,80,000               |                       |



|    |   |              |           |           |      |
|----|---|--------------|-----------|-----------|------|
| 14 | Rectify the harmonic distortion at the Consumer Number 29/3427 and Connect the capacitors for power factor compensation.  |              |           |           |      |
| 15 | Provide a 20 kVAR capacitor (5% of transformer rating) at the main panel exclusively for transformer compensation (Consumer No: 29/3427) during night/ low load period. |              |           |           |      |
| 16 | Ensure proper closing/ Insulation of doors and windows in the air conditioned area to avoid additional heat load to the air conditioner.                                |              |           |           |      |
| 17 | Set the air conditioning area temperature within a range of 24 <sup>o</sup> c to 26 <sup>o</sup> c to have better human comfort and hence to save power.                |              |           |           |      |
| 18 | Avoid the usage of lights during daytime where enough natural lighting is available.  |              |           |           |      |
| 19 | It is Strongly recommended to switch off lights, fans, A/c's as and when the person leaves the plakhe as well as after office hours                                     |              |           |           |      |
| 21 | Replace the existing CRT monitors of the computers with LCD monitors as the power consumption will be reduced by 70%.   |              |           |           |      |
|    | Total Savings   | 4,44,061 kWh | 43,63,685 | 19,12,200 | 5.25 |

A total amount of assured savings of Rs 43, 63,685 /- with an estimated investment of Rs 19, 12,200 /-. If we consider a simple pay back for the total investment we can understand that it is less than a year.

### 5.3. Government Medical College, Thiruvananthapuram

Audited by: Energetic Consultants, Thane

#### INTRODUCTION

The Government Medical College was inaugurated by Pandit Jawaharlal Nehru, architect of our nation on 27<sup>th</sup> November 1951. The inception of the Trivandrum Medical College the first Medical College of the State, a first class teaching hospital with 450 beds was built. The Medical College Hospital was formally inaugurated by the Prime Minister Sri. Jawaharlal Nehru on 8<sup>th</sup> February 1954. There was already an excellent women and children hospital in the campus built by the Royal family in memory of Prince Sree Avittam Thirunal. Hostels for men and women, Nursing College, Dental College, Pharmacy College, Regional Cancer Centre, Artificial Limb Centre. Sree Chithra Institute and Medical Education residential quarters for the staff etc. were developed in the campus of Trivandrum Medical College. In addition to MBBS course, PG degree and diploma courses in 22 specialties, superspeciality courses in 10 specialties, BSc. Nursing, B.Pharm, B.Sc MLT, Para medical courses, Diploma in Pharmacy course etc. are conducted in this institution.

Energy Audit study was conducted on following buildings from the Hospital campus:

1. Medical college hospital main building
2. Power laundry
3. Sree Avittam Thirunal Hospital building
4. Medical college building
5. Principal office building
6. College of pharmaceutical sciences
7. Priyadarshini Institute of paramedical sciences (PIPMS)
8. Water pump house

#### Executive Summary of Savings Identified

| Reference area  | Annual Energy Saving (kWh) | Annual Cost Saving (Rs.) | Capital Investment (Rs.) | Payback Period (months) | ROI (%) | IRR (%) |
|---|----------------------------|--------------------------|--------------------------|-------------------------|---------|---------|
| Cooling tower for package chillers                      | 2,51,870                   | 1,259,351                | 1,000,000                | 10                      | 126     | 126     |
| Cooling load reduction on Blood Bank AC's               | 27,957                     | 1,39,784                 | Nil                      | Immediate               | NA      | NA      |
| Centralized chiller for SAT hospital OT's               | 67,181                     | 3,35,903                 | 1,000,000                | 36                      | 34%     | 31%     |
| Replacement of V- Belts with Flat belts                 | 2279                       | 11,395                   | 33,000                   | 35                      | 35%     | 21%     |
| Cooling tower blade Replacement                         | 2440.8                     | 12,204                   | 10,000                   | 10                      | 122     | 122     |
| Installation of temperature controller on Cooling tower | 2928.96                    | 14,645                   | 2,000                    | 2                       | 732     | 732     |

| <b>Reference area</b>   | <b>Annual Energy Saving (kWh)</b> | <b>Annual Cost Saving (Rs.)</b> | <b>Capital Investment (Rs.)</b> | <b>Payback Period (months)</b> | <b>ROI (%)</b> | <b>IRR (%)</b> |
|---|-----------------------------------|---------------------------------|---------------------------------|--------------------------------|----------------|----------------|
| Solar hot air generation system for laundry dryers            | 30,992                            | 1,54,960                        | 8,00,000                        | 62                             | 19             | 18             |
| Replacement of T12 Tube with T5 tube                          | 2,78,956                          | 1,394,778                       | 1,937,600                       | 17                             | 72             | 51             |
| Replacement of bulbs with CFL                                 | 38,664                            | 1,93,320                        | 26,850                          | 2                              | 720            | 709            |
| Replacement of existing ceiling fans by energy efficient fans | 81,144                            | 4,05,720                        | 11,59,200                       | 34                             | 35             | 29.5           |
| <b>Total</b>  | <b>7,84,413</b>                   | <b>39,22,060</b>                | <b>59,68,650</b>                | <b>18.26</b>                   |                |                |

#### 5.4. Regional Cancer Centre (RCC), Thiruvananthapuram

Audited by: FICCI, New Delhi

Regional Cancer Centre (RCC), one of the prestigious comprehensive cancer treatment centre of Govt. of Kerala. It is located in the medical college campus of Trivandrum city. The building established in 1981 is a multi-storied building with total of 19 floors in three sub-buildings. About 700 persons are working in this centre. About 1000 patients on an average occupy the centre. The centre operates round the clock in a year. The Engineering department looks after the management of electric supply, water supply, ventilation & air conditioning, lighting system etc. of the entire facility to ensure proper work environment and comfort of its employees. As explained earlier, the energy conservation has become a foremost requirement in any high rising building which has a connected load of 500 kW and more, the RCC is also no exception.

RCC has a connected load of around 992 kW. As per electricity bills, the electrical energy consumption stands at about 2.5 lakh kWh per month i.e. about Rs 10 Lakh Per month.

#### Executive Summary of Savings Identified

| SN | Reference Area                 | Recommendations   | Expected Savings   | Approx. Investment (Lakh Rs.) | Simple Pay Back Period (years) |
|----|--------------------------------|---|--|-------------------------------|--------------------------------|
| 1  | Electrical Distribution System | Installation of another 1250 kVA transformer in addition to the existing system   | Reliability Improvement of the electrical system considering present load & future load growth |                               |                                |
| 2  | Electrical Distribution System | Enhancing the contract demand up to 800 kVA from 500 kVA  | Rs. 4.5 lakh / annum   | NIL                           |                                |
| 3  | Lighting System                | Retrofitting the FTLs with 20W CFLs in Non-Essential Areas  | 0.65765 lakh kWh /annum  | 0.63                          | 0.23                           |
|    |                                |   | 2.76 Lakh Rs./annum  |                               |                                |
| 4  | Lighting System                | Retrofitting the FTLs with T5 Lamps in essential Areas  | 5.04 lakh kWh /annum   | 10.47                         | 0.5                            |
|    |                                |   | 21.19 Lakh Rs./annum   |                               |                                |
| 5  | Lighting System                | Putting timers for Campus Lights  | 3650 kWh/ annum  | 0.10                          | 0.67                           |
|    |                                |   | 0.15 lakh Rs. /annum   |                               |                                |
| 6  | Central AC                     | Retrofitting 120TR Reciprocating Chiller with 100TR Screw Chiller   | 1.46 lakh kWh/ annum   | 35                            | 5.71                           |
|    |                                |   | 6.13 lakh Rs. /annum   |                               |                                |
| 7  | Central AC                     | Installation of VFDs in Chilled water pumps   | 1.04 lakh kWh/ annum   | 8.43                          | 1.93                           |
|    |                                |   | 4.37 lakh Rs. /annum   |                               |                                |
| 8  | Central AC                     | Insulating damaged / bare chilled water line  | Prohibiting heat ingress to chilled water  | Marginal                      |                                |
| 9  | Central AC                     | Installation of Centralized control panel for AHU operation along with installation of LCD monitor for display of temperature of various floors | 0.32 lakh kWh/annum  | 2.5                           | 2                              |
|    |                                |   | 1.31 lakh Rs. /annum   |                               |                                |

| SN | Reference Area       | Recommendations   | Expected Savings   | Approx. Investment (Lakh Rs.) | Simple Pay Back Period (years) |
|----|----------------------|---|--|-------------------------------|--------------------------------|
| 10 | Water Pumping System | Installation of Auto ON/OFF actuator switch and water level indicator       | 12,213 kWh/annum<br>0.5 lakh Rs./annum                   | 0.5                           | 1                              |
|    |                      | Installation of a syntax water tank for overflow water from different tanks | Waste minimization                                       |                               |                                |
|    |                      | Providing Electronic Energy Meters & Run-Hour Meters for each pump          | Better Energy Monitoring & Accounting                    | 0.2                           |                                |
|    |                      | Running the pump most of the time during off-peak period                    | Reduction of about 18kVA from the present maximum demand | Marginal                      |                                |
| 11 | Boiler               | Condensate Recovery in boiler house at laundry                              | Reduction in Fuel Consumption by 10%                     | Marginal                      |                                |
| 12 | Others               | Providing Electronic Energy Meters at Strategic Locations                   | Energy Monitoring & Accounting                           | 1.0                           |                                |
|    |                      | <b>TOTAL</b>  | 8.67 Lakh kWh/annum<br>40.91 Lakh Rs./ annum             | 59.03                         | 1.44                           |

## 5.5. Mascot Hotel, Thiruvananthapuram

Audited by: FICCI, New Delhi

The Mascot Hotel, one of the prestigious hotels under Kerala Tourism Development Corporation Ltd., Govt. of Kerala is located at the heart of the Trivandrum city. The hotel building renovated in 2004 & 2007 is a multistoried building in three sub-buildings. About 250 employees are working in this hotel which operates round the clock. The Project Engineer (Electrical) looks after the management of electric supply, water supply, ventilation & air conditioning, lighting system etc. of the entire building to ensure proper work environment and comfort of its guests & employees.

Mascot Hotel has a connected load of around 728 kW (As per Inventory Survey). As per electricity bills, the electrical energy consumption stands at about 1.38 lakh kWh per month i.e. about 7.5 Lakh Rs. Per month. However, the total energy bill (electricity, water, diesel & LPG) is about 15 Lakh Rs. Per month.

The detail energy audit reveals that various energy conservation and efficiency options can further result in saving of about Rs. 24.92 lakh per annum and reduce the energy consumption by 1.86 lakh units and 4200 liters of fuel oil per annum (About 14% of the total consumption). The summary of the potential savings has been shown in the following table.

### Executive Summary of Savings Identified

| SN | Area                                 | Recommendations  | Expected Benefit/<br>Saving                      | Approx.<br>Investment<br>(Lakh Rs.) | Simple<br>Pay Back<br>Period<br>(Years) |
|----|--------------------------------------|--|--|-------------------------------------|---|
| 1  | Electrical<br>Distribution<br>System | Running single transformer<br>by switching ON the bus<br>coupler and keeping the<br>other one hot standby        | 5,052 kWh/annum                                  | NIL                                 |   |
|    |                                      |  | 0.25 Lakh Rs./annum                              |                                     |   |
| 2  | Electrical<br>Distribution<br>System | Installation of additional<br>100kVAR capacitor banks<br>at LT main Panel in<br>addition to existing 100<br>kVAR | PF improvement to<br>1.0                         | 1.0                                 | 1.4                                     |
|    |                                      |  | Reducing the<br>Demand by 20 kVA                 |                                     |   |
|    |                                      |  | 0.72 lakh Rs./annum                              |                                     |   |
| 3  | Electrical<br>Distribution<br>System | Reducing the Current<br>Unbalance to 10% in<br>all distribution<br>panels  | Less Cable Loss<br>Reduction in Safety<br>Hazard | NIL                                 |   |
| 4  | Lighting<br>System                   | Retrofitting the T12/T8<br>FTLs with T5 FTLs   | 16,000 kWh /annum                                | 0.66                                | 0.8                                     |
|    |                                      |  | 0.82 Lakh Rs./annum                              |                                     |   |
| 5  | Lighting<br>System                   | Retrofitting the GLS<br>lamps with 11W CFL<br>Lamps  | 84,000 kWh /annum                                | 1.87                                | 0.5                                     |
|    |                                      |  | 4.10 Lakh Rs./annum                              |                                     |   |
| 6  | Central AC                           | Installation of VFDs for<br>Condenser Water Pumps<br>and improving range in<br>cooling towers                    | 67,000 kWh/ annum                                | 4.5                                 | 1.35                                    |
|    |                                      |  | 3.33 lakh Rs./annum                              |                                     |   |

| SN | Area             | Recommendations   | Expected Benefit/<br>Saving                  | Approx.<br>Investment<br>(Lakh Rs.) | Simple<br>Pay Back<br>Period |
|----|------------------|---|--|-------------------------------------|------------------------------|
| 7  | Hot Water System | Rearrangement of hot water distribution system                    | 4,380 kWh/annum                              | 0.2                                 | 1                            |
|    |                  |   | 0.22 lakh Rs./annum                          |                                     |                              |
| 8  | Hot Water System | Installation of Solar Hot Water system                            | 4,200 liters of fuel                         | 9.6                                 | 0.64                         |
|    |                  |   | 15.0 Lakh Rs./annum                          |                                     |                              |
| 9  | Others           | Insulating the lower portion of the electric press at the laundry | 9,720 kWh/annum                              | 0.1.                                | 0.2                          |
|    |                  |   | 0.48 lakh Rs./annum                          |                                     |                              |
| 10 | Others           | Repairing the damaged portion of the exhaust ducts of kitchen     | Better ventilation in kitchen area           | Marginal                            |                              |
| 11 | Others           | Providing Electronic Energy Meters at Strategic Locations         | Better Energy Monitoring & Accounting        | 0.50                                |                              |
|    | <b>TOTAL</b>     |   | 1,86,152 kWh/annum & 4200 ltr of fuel /annum | 18.43                               | 0.74                         |
|    |                  |   | 24.92 Lakh Rs./annum                         |                                     |                              |

## 5.6. Vydyuthi Bhawan, Thiruvananthapuram

Audited by: FICCI, New Delhi

Vydyuthi Bhawan, the headquarters of KSEB is located at heart of the Trivandrum city. The building established in 1985 is a multi-storied building with a total of ten floors. About 1200 employees are working in this office with office hour of 8 hours in week days and Saturday. The Executive Engineer, Civil Division looks after the management of electric supply, water supply, ventilation & air conditioning, lighting system etc. of the entire building to ensure proper work environment and comfort of its employees.

Vydyuthi Bhawan has a connected load of around 475 kW (As per Inventory Survey). As per electricity bills, the electrical energy consumption stands at about 0.5 lakh kWh per month i.e. about 2.5 Lakh Rs. Per month (@Rs. 5/- per Unit).

The detail energy audit reveals that various energy conservation and efficiency options can further result in saving of about Rs. 9.3 lakh per annum and reduce the energy consumption by 1.8 lakh units per annum (About 30% of the total consumption). The summary of the potential savings has been shown in the following table.

### Executive Summary of Savings Identified

| SN  | Area                                  | Recommendations   | Expected Benefit              | Approx. Investment (Lakh Rs.) | Simple Pay Back Period (Years) |
|---|---------------------------------------|---|-------------------------------|-------------------------------|--------------------------------|
| 1   | Electrical Distribution System        | Installation of 100kVAR (4x25) capacitor banks at LT main Panel of VB Feeder  | PF improvement to 0.99        | 1.0                           | NA                             |
|   |                                       |   | Reducing the Demand by 30 kVA |                               |                                |
| 2   | Lighting System                       | Retrofitting the FTLs with 18W CFLs in Non-Essential Areas  | 18527 kWh /annum              | 0.5                           | 0.54                           |
|   |                                       |   | 0.93 Lakh Rs./annum           |                               |                                |
| 3   | Lighting System                       | Retrofitting the FTLs with T5 Lamps in essential Areas  | 73,113 kWh /annum             | 9.14                          | 2.5                            |
|   |                                       |   | 3.66 Lakh Rs./annum           |                               |                                |
| 4   | Comfort AC System (Package AC)        | Blocking a portion of the AC duct and providing 1.5TR split AC in one office room in 7 <sup>th</sup> floor          |                               | 0.2                           |                                |
|   |                                       | Providing Sun films for entire window glasses which are exposed to sun light in 7 <sup>th</sup> floor               | Better cooling effect         | 1                             |                                |
|   |                                       | Proper Insulation of Delivery duct of Package AC's  | Better cooling effect         | 0.5                           |                                |
|   |                                       | Replacing the 10TR#1 & 10TR#2 with one 16.5TR Air Cooled Package AC with Scroll Compressor in 7 <sup>th</sup> Floor | 60,855 kWh/annum              | 6                             | 1.97                           |
|   |                                       |   | 3.04 Lakh Rs./annum           |                               |                                |
| Installation of Electronic Energy Meter for main AC Plant Panel in 7 <sup>th</sup> floor & 10 <sup>th</sup> Floor | Better Energy Monitoring & Accounting | 0.2   |                               |                               |                                |



|   |                                |   |                                       |      |     |
|---|--------------------------------|---|---------------------------------------|------|-----|
|   | Comfort AC System (Window AC ) | Replacing the old units with BEE star rated AC units                                    | 23,772 kWh/annum                      | 3.5  | 1.2 |
|   |                                |   | 1.2 Lakh Rs./annum                    |      |     |
| 5 | Water Pumping System           | Installation of Auto ON/OFF actuator switch and water level indicator                   | 6,577 kWh/annum                       | 0.4  | 1.2 |
|   |                                |   | 0.33 Lakh Rs./annum                   |      |     |
|   |                                | Installation of a syntax water tank for overflow water from 4 <sup>th</sup> Floor tanks | Waste minimization                    | 0.1  |     |
|   |                                | Providing Electronic Energy Meters & Run-Hour Meters for each pump                      | Better Energy Monitoring & Accounting | 0.2  |     |
| 6 | Others                         | Providing Electronic Energy Meters at Strategic Locations                               | Better Energy Monitoring & Accounting | 0.3  |     |
|   | <b>TOTAL</b>                   |   | 1,82,844 kWh/annum                    | 23.0 | 2.5 |
|   |                                |   | 9.16 Lakh Rs./ annum                  |      |     |

## 5.7. State Bank of Travancore, Thiruvananthapuram

Audited by: BSNL, Thiruvananthapuram

State Bank of Travancore Complex, set in a quiet residential locality has an imposing Main building having G+7 Floors with 3 smaller buildings spread over the rear side. Constructed in the year 1983, this complex has the following features to make the settings of a vibrant corporate Head Quarters.

### Block wise Plinth Area Details of Building

| Name of Block         | Year of Construction | No. of floors | Plinth Area |
|-----------------------|----------------------|---------------|-------------|
| Main Bldg.            | 1983                 | 8             | 5917 sq.m   |
| Annex Building        | 1983                 | 3             | 1511 sq.m   |
| Staff Training Centre | 1983                 | 3             | 2658 sq.m   |
| NAC Branch Bldg.      | 1982                 | 2             | 952 sq.m    |
| Total Area            |                      |               | 11038 sq.m  |

Contract Demand : 565kVA  
 Recorded Maximum Demand (RMD) : 387 kVA (Average)

Fixed Charge & Energy charge : Rs350/kVA&Rs3.70/kWh for HT  
 Rs170/kVA&Rs8.30/kWh for LT

Annual Electricity Charges : Rs 53, 73,439/- for HT  
 Rs 9, 78,168/- for LT

### Executive Summary of Savings Identified

| Sl. No   | Energy saving Recommendations  | Technical Target  | Annual savings (Rs. Lakh) | Capital investment (Rs. Lakh) | Simple pay back period (years) | Return on Investment (%) | Internal Rate of Return (%) |
|----------|--|---|---------------------------|-------------------------------|--------------------------------|--------------------------|-----------------------------|
| <b>A</b> | <b>Electrical Distribution System</b>  |   |                           |                               |                                |                          |                             |
| 1        | Reduction in Contract Demand   | Curtailling unnecessary payment   | 1.11                      | Nil                           | NA                             |                          |                             |
| 2        | Induction of STC LT Load in Existing HT Supply   | Deriving HT Tariff Advantage  | 1.24                      | 0.25                          | 0.20                           | 494.0                    | 514.5                       |
| 3        | Redesigning APFC Panel with fine controls  | Ensuring improved power factor and minimizing energy loss during peak & off peak period | 6.13                      | 3.00                          | 0.49                           | 180.99                   | 197                         |
| <b>B</b> | <b>Lighting System</b>   |   |                           |                               |                                |                          |                             |
| 4        | Replacement of 2x40w fluorescent fittings with 2 x 28 w Mirror optic T5 Fittings in office halls | Induction of energy efficient technology  | 1.15                      | 3.41                          | 3                              | 33.83                    | 25.4                        |

| Sl. No       | Energy saving Recommendations  | Technical Target  | Annual Saving (Rs. Lakh) | Capital investment (Rs. Lakh) | Simple pay back period (years) | Return on Investment (%) | Internal Rate of Return (%) |
|--------------|--|---|--------------------------|-------------------------------|--------------------------------|--------------------------|-----------------------------|
| 5            | Replacement of 40w incandescent lamps with 11 w CFL in Reading Lamps                   | Induction of energy efficient technology  | 0.12                     | 0.07                          | 0.6                            | 167.44                   | 167                         |
| 6            | Replacement of 1x40w fluorescent fittings with 1 x 11 w CFL Fittings in Toilets        | Induction of energy efficient technology  | 0.11                     | 0.15                          | 1.3                            | 76.6                     | 76                          |
| 7            | Replacement of resistance type regulators with energy efficient Electronic regulators. | Adopting energy efficient technology to curtail wastage                             | 0.06                     | 0.09                          | 1.6                            | 62.16                    | 62                          |
| <b>C</b>     | <b>HVAC System</b>   |   |                          |                               |                                |                          |                             |
| 8            | Providing inter locks to stop condensers with compressors                              | Tapping available opportunity to cut energy wastage                                 | 0.07                     | 0.05                          | 0.67                           | 148.6                    | 147                         |
| 9            | Replacement of in efficient and life expired WAC/SAC units,                            | Inducting efficient technology to improve efficiency                                | 1.31                     | 4.19                          | 3.20                           | 31.30                    | 21.9                        |
| <b>D</b>     | <b>Pumping System</b>  |   |                          |                               |                                |                          |                             |
| 10           | Replacement of 1No 10HP centrifugal pump set by energy efficient submersible pump set  | Deriving optimum efficiency through better design, where Replacement is already due | 0.10                     | 0.35                          | 3.48                           | 28.71                    | 26                          |
| 11           | Replacement of 1No 1.5HP Jet pump set by energy efficient submersible pump set         | Enhancing energy efficiency through better design to suit local need                | 0.24                     | 0.12                          | 0.5                            | 198.15                   | 199                         |
| 12           | Replacement of Lift motors with lower capacity   | To reduce energy loss due to over rated motors                                      | 0.22                     | Nil                           | NA                             |                          |                             |
| <b>E</b>     | <b>Energy Monitoring</b>   |   |                          |                               |                                |                          |                             |
| 13           | Providing individual Energy meters for Major Loads                                     | Effective Energy monitoring and improved energy management                          | 2.70                     | 2.04                          | 0.75                           | 133.3                    | 193                         |
| <b>F</b>     | <b>Renewable Energy Measures</b>   |   |                          |                               |                                |                          |                             |
| 14           | Bio Gas Plant (20 M <sup>3</sup> ) for utilization of biomass.                         | Tapping renewable energy from bio waste   | 1.00                     | 2.45                          | 2.44                           | 40.91                    | 40                          |
| 15           | Additional Rain water harvesting system for Main Block & Annex Bldg                    | Enlarging tapping of Bountiful rain water.  | 0.46                     | 0.50                          | 1.1                            | 107.89                   | 90                          |
| <b>TOTAL</b> |  |   | 16.02                    | 16.67                         | 1.04                           |                          |                             |

## 5.8. Shakthan Thampuran Arcade, Thrissur

Audited by: FICCI, New Delhi

Shakthan Thampuran Arcade (STA), one of the shopping complexes in Thrissur City of Kerala is located near to Thrissur Municipality office. Apart from housing various shops, the arcade also houses the office of Kerala Sustainable Urban Development Project (KSUDP). The building established in 2006 is a multi-storied building with total of six floors. Only the first floor and ground floor are occupied (still partially) and rest of the floors is still un-occupied. The KSUDP office is located in the 2<sup>nd</sup> floor of the arcade. The working hour of the shops is about 11 hours in per day except the KSUDP office which works for about 8 hours per day. The Executive Assistant Engineer (Electrical) of Thrissur Municipality looks after the operation & maintenance of KSUDP office only.

It is seen that the power factor is only 0.8 which is very low. As there is no reactive power compensation through capacitor banks, more kVA (hence more current) is demanded for the same load. The power factor improvement can be done by installation of capacitor banks. But, as there is very little load now and load addition is expected in near future, the size of the capacitor bank could not be calculated. It is suggested to look into this matter by the KSEB authority to ensure PF of 0.99 by installation of suitable capacitor bank. 1.8 The total kVA is recorded as 24.4 kVA. So, the loading of the installed transformer is only 9.76% which is very low. This under loading is leading to poor efficiency as well.

As the lux level is very low, it is suggested to improve the lighting system. It is seen that for this kind of office space CFL could be a better option. It is suggested to install "LEVEL INDICATOR as well as AUTO ON/OFF switch" for the pumps in order to optimize the run hour. Considering the pumping capacity and requirement for consumption, a conservative estimation shows that there would be at least 30% reduction in energy consumption due to water pumps. This can be saved per year in addition to precious water source with marginal investment.

### Summary

As out of the total six floors of the building, only first floor and ground floor is occupied that too partially. The list of recommendation that are presentable is limited to the following

- Power Factor improvement from the present value of 0.8
- Presently the transformer loading is only 9.76 %
- The illumination level is found to be very low
- Operation of water pumps to be controlled and rationalized

## 5.9. Mail Business Centre, Thiruvananthapuram

Audited by: FICCI, New Delhi

Mail Business Centre has a connected load of around 30 kW (As per Inventory Survey). As per electricity bills, the electrical energy consumption stands at about 7778 kWh per month. The total energy bill stands at about 1.0 Lakh Rs. Per month which includes electricity, diesel, water & LPG.

The detail energy audit reveals that various energy conservation and efficiency options can further result in saving of about Rs. 1.0 lakh per annum and reduce the energy consumption by 0.21 lakh units per annum (About 22% of the total consumption). The summary of the potential savings has been shown in the following table.

### Executive Summary of Savings Identified

| SN           | Area            | Recommendations   | Expected Benefit  | Approx. Investment (Lakh Rs.) | Simple Pay Back Period (years) |
|--------------|-----------------|---|---|-------------------------------|--------------------------------|
| 1            | Lighting System | Retrofitting the FTLs with 18W CFLs in Non-Essential Areas                              | 8,042 kWh /annum  | 0.09                          | 0.2                            |
|              |                 |   | 0.40 Lakh Rs./annum   |                               |                                |
| 2            | Lighting System | Retrofitting the FTLs with T5 Lamps in essential Areas                                  | 12,141 kWh /annum   | 1.2                           | 2                              |
|              |                 | Providing 'Pull switch' for FTLs at Ground Floor  | 0.60 Lakh Rs./annum   |                               |                                |
| 3            | Others          | Providing voltmeter, ammeter for LT main panel, Energy meter, run-hour meter for DG set | Better Energy Monitoring & Accounting                       | 0.2                           |                                |
|              |                 | Replacing the existing LT main panel with new one                                       | Improving reliability and reducing electrical safety hazard | 0.5                           |                                |
| <b>TOTAL</b> |                 |   | 20,183 kWh/annum  | 1.99                          | 2                              |
|              |                 |   | 1.0 Lakh Rs./annum  |                               |                                |

## 5.10. The Kerala State Planning Board, Thiruvananthapuram

Audited by: BSNL, Thiruvananthapuram

The Kerala State Planning Board is a Government body, which supports the State Government to formulate their development plans based on scientific assessment of the resources of the State and the growth priorities. The board is responsible for planning and review of the activities covering all spheres of development of the state of Kerala in line with the Central five-year plans. The Chairman of the State Planning Board is the Chief Minister of the State, presently, Shri. V. S. Achuthanandan. The Planning Board Vice Chairman, Shri. Prabhath Patnaik is a well known economist of international repute and a prominent personality of our country.

The State Planning Board is housed in two blocks, one old block and the other new block. The old block of vintage construction, is set up in sylvan settings of native flora all around. The very settings and the rich tree cover of the old block, makes the ventilation and air conditioning demand of this block very less. On the other hand, the new block (G+6), facing west, when completed will have excess demand of energy due to heat gain through the western and southern wall as well as glass area.

### Summary of Energy Saving Recommendations

| Sl.No     | Energy saving Recommendations at a Glance  | Technical Target                                   | Annual Energy Saving (kWh) | Annual Cost Savings (Rs.) | Capital Investment (Rs.) | Simple Pay Back Period | Return on Investment (%) | Internal Rate of Return (%) |
|-----------|--|--|----------------------------|---------------------------|--------------------------|------------------------|--------------------------|-----------------------------|
| <b>I</b>  | <b>Electrical Distribution System</b>  |  |                            |                           |                          |                        |                          |                             |
| 1         | Load Balancing to reduce the neutral current and cleaning and tightening of terminals                                  | Reducing Wastage of Energy                         | 402                        | 3,000                     | 3,600                    | 14.4 months            | 83.3                     | 101                         |
| 2         | Use of LED type Indication lamps in LT Panels  | Enhancing energy efficiency                        | 237                        | 1,398                     | 450                      | 4 months               | 311                      | 312                         |
| 3         | Providing APFC Panel for improving the PF  | Enhancing energy efficiency                        |                            | 36,192                    | 92,752                   | 2.56 years             | 39                       | 36                          |
| <b>II</b> | <b>Lighting System</b>   |  |                            |                           |                          |                        |                          |                             |
| 4         | Use of Energy Efficient FTL with electronic Choke (Retrofit type) in plakhe of conventional FTL with magnetic ballasts | Enhancing energy efficiency                        | 12,528                     | 78,667                    | 2,81,880                 | 43 months              | 28                       | 22                          |
| 5         | Replacement of GLS Lamps with CFL  | Implementation of energy efficiency                | 3,069                      | 19,856                    | 6,642                    | 4 months               | 300                      | 297                         |
| 6         | Replacement of HPSV Lamps with Metal halide lamps  | Enhancing energy efficiency                        | 3,154                      | 18,606                    | 15,600                   | 10 months              | 119                      | 118                         |
| 7         | Use of Natural light, Awareness, etc ENCON options 4,5,6 under LIGHTING  | Tapping natural resources for sustain-able habitat | 840                        | 5,452                     | 0                        | 0                      | Full                     | Full                        |

|            |   |   |                      |        |          |             |       |       |
|------------|---|---|----------------------|--------|----------|-------------|-------|-------|
| 8          | Replacement of Resistance type Regulators with Electronic Regulators  | Enhancing energy efficiency                               | 7,279                | 42,946 | 29,880   | 8.35 months | 144   | 139   |
| 9          | Disconnecting the faulty HPSV lamp drawing 16 W power but not glowing   | Reducing Wastage of Energy                                | 140                  | 910    | 0        | 0           | Full  | Full  |
| <b>III</b> | <b>Computers</b>  |   |                      |        |          |             |       |       |
| 10         | Replacement of CRT Monitors with LCD or TFT Monitors  | Enhancing energy efficiency                               | 9,500                | 64,360 | 2,83,500 | 4.4 years   | 22.7  | 4.38  |
| <b>IV</b>  | <b>Air-Conditioning System</b>  |   |                      |        |          |             |       |       |
| 11         | Cleaning of dirty condenser, evaporator, filters, Replacement of capacitors, topping up R-22etc                   | Enhancing energy efficiency                               | 4,666                | 27,529 | 15,600   | 7 months    | 176   | 160   |
| <b>V</b>   | <b>DG System</b>  |   |                      |        |          |             |       |       |
| 12         | Doing special maintenance to reduce SFC (Already the DG is under AMC)   | Enhancing energy efficiency                               | 270 Ltrs of HSD      | 8,190  | NIL      | 0           | Full  | Full  |
| <b>VI</b>  | <b>Energy Monitoring &amp; Targeting</b>  |   |                      |        |          |             |       |       |
| 13         | By energy monitoring and increasing awareness by providing Energy Meters at load centers                          | Better management Through Energy monitoring and Targeting | 1608                 | 12,000 | 20,000   | 20 months   | 60    | 61    |
| <b>VII</b> | <b>Tapping Renewable Sources</b>  |   |                      |        |          |             |       |       |
| 14         | Providing Solar Water heaters of 600 Ltrs. Capacity for Canteen   | Tapping Solar power under national solar mission          | 1010 Kg of LPG       | 42,420 | 10,5000  | 2.48 years  | 40.4  | 33.26 |
| 15         | Providing Roof top Rain Water Harvesting  | Tapping natural resources for sustainable habitat         | 900 K. Ltrs of Water | 22,500 | 20,000   | 11 months   | 102   | 111.2 |
| 16         | Providing Small Wind cum solar Hybrid energy system (3.3KW wind +1.7KW solar) for feeding power to selected load. | Tapping Solar and Wind power under national solar mission | 6,400                | 41,536 | 4,10,000 | 9.78 years  | 10.13 | 5.15  |
|            | <b>TOTAL</b>  |   | 49823                | 425562 | 1284904  | 3 years     |       |       |

Total Electricity Saving

: 49,823 kWh

Total Diesel Saving

: 270 Ltrs

Total Water Saving

: 900 Kilo Ltrs

Total LPG Saving

: 1010 Kg

Total Investment

: Rs. 12, 84,904/-

Pay Back In The 1st Year Itself: Rs.4, 25,562/-

## 5.11. General Post Office Building, Thiruvananthapuram

Audited by: BSNL, Thiruvananthapuram

The GPO building, Thiruvananthapuram is the General Post Office of the city of Thiruvananthapuram, where all postal requirements of a citizen can be fully met. The building is visited by general public in large numbers every day, including evening hours. Being the abode for all kinds of postal activities like selling postal articles, sorting, registering, management of Postal Life Insurance, philatelic bureau etc, this building also accommodate the offices of Director, Postal Accounts Kerala Circle and Postal Division of North Thiruvananthapuram .

Annual Electricity Charges : Rs. 9.07 Lakh

Annual Diesel Consumption

(DG Set) : 525 Ltrs (Approx)

Annual Fuel (HSD) Charges : Rs. 18,056/-

Annual Water Consumption : 3,308 Kilo Ltrs

Annual Water Charges : Rs. 78168/-

(Will be more next year, since tariff has changed w.e.f. 01.09.2008)

Annual LPG consumption : 3,067 Kg

### Summary of Energy Saving Recommendations

| Sl. No   | Energy saving Recommendations at a Glance   | Technical Target            | Annual Energy Saving KWH | Annual Cost Savings (Rs.) | Capital Investment (Rs.) | Simple Pay Back period | Return on Investment (%) | Internal Rate of Return (%) |
|----------|---|-----------------------------|--------------------------|---------------------------|--------------------------|------------------------|--------------------------|-----------------------------|
| <b>1</b> | <b>Electrical Distribution System</b>   |                             |                          |                           |                          |                        |                          |                             |
| 1        | Reduction of Contract Demand (125 KVA to 80 KVA)                                      | Rationalization of CD       |                          | 1,00,000                  | NIL                      | NA                     | NA                       | NA                          |
| 2        | Load Balancing to reduce the neutral current and cleaning and tightening of terminals | Reducing Wastage of Energy  | 5,188                    | 27,201                    | 3,600                    | 1.59 Months            | 756                      | 800                         |
| 3        | Rectification of Earth leakage from SDF unit in LT panel                              | Reducing wastage of Energy  | 263                      | 868                       | NIL                      | NA                     | NA                       | NA                          |
| 4        | Use of LED type Indication lamps in lift M/C room panel                               | Enhancing energy efficiency | 474                      | 1,564                     | 900                      | 6.92 Months            | 173                      | 177                         |
| 5        | Servicing of APFC Controller and Panel to increase PF from 0.94 to Unity              | Reactive Power Management   | NA                       | 19,069                    | 4,500                    | 2.83 Months            | 424                      | 420                         |



| Sl. No                               | Energy saving Recommendations at a Glance   | Technical Target                                       | Annual Energy Saving KWH | Annual Cost Savings (Rs.) | Capital Investment (Rs.) | Simple Pay Back period | Return on Investment (%) | Internal Rate of Return (%) |
|--------------------------------------|---|--|--------------------------|---------------------------|--------------------------|------------------------|--------------------------|-----------------------------|
| <b>II Lighting System</b>            |   |  |                          |                           |                          |                        |                          |                             |
| 6                                    | Use of Energy Efficient FTL with electronic Choke (Retrofit type) in place of conventional FTL with magnetic ballasts | Enhancing Energy Efficiency                            | 18,560                   | 95,448                    | 3,14,766                 | 3.3 Years              | 30                       | 23                          |
| 7                                    | Replacement of GLS Lamps with Energy efficient CFL  | Enhancing Energy Efficiency                            | 3,863                    | 15,923                    | 2,214                    | 1.67 Months            | 719                      | 720                         |
| 8                                    | Use of Natural light, and implementing ENCON options 4,5,6 under Lighting   | Tapping natural resources for sustainable habitat      | 5,986                    | 19,753                    | NIL                      | NA                     | NA                       | NA                          |
| 9                                    | Replacement of Resistance type Regulators with Electronic Regulators  | Enhancing Energy Efficiency                            | 8,550                    | 41,485                    | 35,100                   | 10.15 Months           | 118                      | 115                         |
| <b>III UPS &amp; Computer System</b> |   |  |                          |                           |                          |                        |                          |                             |
| 10                                   | Replacement of CRT Monitors with LCD or TWT Monitors  | Enhancing Energy Efficiency                            | 10,556                   | 1,24,106                  | 2,80,000                 | 5.17 Years             | 44.32                    | 31                          |
| <b>IV Air-Conditioning System</b>    |   |  |                          |                           |                          |                        |                          |                             |
| 11                                   | Cleaning of dirty condenser, evaporator, filters, Replacement of capacitors, topping up R-22etc                       | Improving efficiency thru better maintenance practices | 18,374                   | 60,636                    | 12,000                   | 2.37 Months            | 505                      | 407                         |
| <b>V DG System</b>                   |   |  |                          |                           |                          |                        |                          |                             |
| 12                                   | Doing special maintenance to reduce SFC (Already the DG is under AMC)   | Improving efficiency thru better maintenance practices | 158 Lts of HSD           | 5,214                     | 1,000                    | 2.3 Months             | 521                      | 525                         |

| Sl. No                                      | Energy saving Recommendations at a Glance   | Technical Target                               | Annual Energy Saving kWh | Annual Cost Savings (Rs.) | Capital Investment (Rs.) | Simple Pay Back period | Return on Investment (%) | Internal Rate of Return (%) |
|---|---|--|--------------------------|---------------------------|--------------------------|------------------------|--------------------------|-----------------------------|
| <b>VI Energy Monitoring &amp; Targeting</b> |   |  |                          |                           |                          |                        |                          |                             |
| 13  | Providing Energy Meters floor or section wise for effective monitoring of Energy consumption and creating awareness among staff | Energy monitoring and Targeting                | 17,294                   | 57,072                    | 26,000                   | 5.47 Months            | 220                      | 221                         |
| <b>VII Tapping Renewable Sources</b>        |   |  |                          |                           |                          |                        |                          |                             |
| 14  | Providing Solar Water heaters of 600 Lts capacity for Canteen   | Tapping natural resources to meet part demand. | 1,010 Kg of LPG          | 23,230                    | 1,05,000                 | 2.48 Years             | 22.12                    | 20                          |
| 15  | Providing Roof top Rain Water Harvesting  | Tapping natural resources to meet part demand. | 590 K.Lts of Water       | 14,761                    | 20,000                   | 16 Months              | 74                       | 87                          |
| 16  | Bio Gas Plant (15 M <sup>3</sup> ) for utilization of biomass.  | Tapping renewable energy from bio waste        | 1,496 kg of LPG          | 46,946                    | 2,25,000                 | 4.79 Years             | 21                       | 10                          |
|   | <b>TOTAL</b>  |  | 89108                    | 653276                    | 1030080                  | 1.57 Years             |                          |                             |

Total Electricity Saving: 89,108 kWh      Total Diesel Saving : 158 Ltrs  
Total Water Saving : 590 Kilo Ltrs      Total LPG Saving : 2,506 Kg  
Total Investment : Rs. 10, 300, 80/-      Pay Back In The 1<sup>st</sup> Year Itself: Rs. 6, 53,276/-

The total investment on various items would be paid back within one year and nine months and for the remaining life period of the invested projects; it would definitely yield very good returns or profit Having seen various options, with their individual cost benefit analysis in a nutshell, one can move forward to take a closer look of different systems in the ensuing chapters.

## 5.12. Rajiv Gandhi Centre of Biotechnology, Thiruvananthapuram

Audited by: FICCI, New Delhi

Rajiv Gandhi Centre of Biotechnology (RGCB) has a connected load of around 591 kW (As per Inventory Survey). As per electricity bills, the electrical energy consumption stands at about 1.385 lakh kWh per month i.e. about 7.5 Lakh Rs. per month.

### Executive Summary of Savings Identified

| SN | Area                           | Recommendations   | Expected Benefit / Saving                                      | Approx. Investment (Lac Rs.) | Simple Pay Back Period | ROI (%) | IRR (%) |
|----|--------------------------------|---|--|------------------------------|------------------------|---------|---------|
| 1  | Electrical Distribution System | Installation of additional 90KVAR capacitor banks at LT main Panel in addition to existing 160 KVAR   | PF improvement to 1.0  | 0.90                         |                        | NA      | NA      |
|    |                                |   | Reducing the Demand by 25 KVA                                  |                              |                        |         |         |
|    |                                |   | Financial benefit to be reflected in the bill as per MD record |                              |                        |         |         |
| 2  | Electrical Distribution System | Reducing the Current Unbalance to 10% in all distribution panels  | Less Cable Loss<br>Reduction in Safety Hazard                  | NIL                          |                        |         |         |
| 3  | Lighting System                | Retrofitting the FTLs with 20W CFLs in Non-Essential Areas  | 19000 KWH /Annum   | 0.3                          | 0.31 years             | 320     | 319.99  |
|    |                                |   | 0.96 Lac Rs./Annum   |                              |                        |         |         |
| 4  | Lighting System                | Retrofitting the FTLs with T5 Lamps in essential Areas  | 108000 KWH /Annum  | 6                            | 1 years                | 100     | 97.98   |
|    |                                |   | 6 Lac Rs./Annum  |                              |                        |         |         |
| 5  | Lighting System                | Replacement of Incandescent lamps with 20W CFL  | 21000 KWH /annum<br>1 lac Rs. /annum                           | 1                            | 1 years                | 100     | 97.98   |
| 6  | Lighting System                | Putting timers for Campus lights  | 7300 KWH/ annum<br>0.4 lac Rs. /annum                          | 0.10                         | 0.26 years             | 400     | 399.90  |
| 7  | Central AC                     | Setting the Chilled water delivery side temperature at 8.0 °C during off-peak seasons   | 54000 KWH/ annum<br>2.8 lac Rs. /annum                         | NIL                          |                        |         |         |
| 8  | Central AC                     | Installation of Centralized control panel for AHU operation along with installation of LCD monitor for display of temperature of various floors | 24710 KWH/annum<br>0.4 lac Rs. /annum                          | 1.5                          | 1.4 years              |         |         |
| 9  | Comfort AC System (Window AC)  | Replacing the old units with BEE star rated AC units  | 25600 KWH/Annum  | 2.4                          | 1.8 years              | 55.42   | 55.21   |
|    |                                |   | 1.33 Lac Rs./Annum   |                              |                        |         |         |

|    |                      |   |                                       |           |                   |  |  |
|----|----------------------|---|---------------------------------------|-----------|-------------------|--|--|
| 10 | DG Sets              | Putting additional 60-80 KW load on the DG set                              | About 18 liters of Diesel/hour        | NIL       |                   |  |  |
| 11 | Water Pumping System | Installation of Auto ON/OFF actuator switch and water level indicator       | 4520 KWH/Annum                        | 0.5       | 2.0 years         |  |  |
|    |                      |   | 0.24 Lac Rs./Annum                    |           |                   |  |  |
|    |                      | Installation of a syntax water tank for overflow water from different tanks | Waste minimization                    | 0.1       |                   |  |  |
|    |                      | Providing Electronic Energy Meters & Run-Hour Meters for each pump          | Better Energy Monitoring & Accounting | 0.2       |                   |  |  |
| 12 | Others               | Providing Electronic Energy Meters at Strategic Locations                   | Better Energy Monitoring & Accounting | 1.0       |                   |  |  |
|    | <b>TOTAL</b>         |   | <b>264130 KWH/Annum</b>               | <b>14</b> | <b>1.06 Years</b> |  |  |
|    |                      |   | <b>13.13 Lakh Rs./ Annum</b>          |           |                   |  |  |

### 5.13. BSNL-The Panampilly Nagar Telephone Exchange, Ernakulam

Audited by: BSNL, Thiruvananthapuram

Bharat Sanchar Nigam Ltd., the World's 7th largest Telecommunication Company is providing comprehensive range of Telecom services in India. BSNL has spent Rs.1606 crores in 2007-2008 and Rs.1533 crores in 2006-2007 respectively, towards Energy charges (Electricity and Fuel). The energy cost alone accounts for around 20% of total operating cost of this Public sector undertaking.

The Panampilly Nagar Telephone Exchange, one of the important links in the chain of Telecom Net work of the country, is a very vital Telephone Exchange in Ernakulam. This Telephone Exchange was commissioned in 1992 as E10B exchange. Since then, more switches have been added and at present three major Exchanges viz. E 10B, GSM MSC and Digital Transmission Exchanges are accommodated in the building. Source of energy for the building is KSEB grid supply at 11kV, 3 Phase, which is stepped down to 433V through 2 Nos 750kVA indoor Transformers. There are 2 No.s 500 kVA EA sets to act as standby power source.

#### Other vital features of the building are,

|   |  |
|---|--|
| Area of Land                            | : 60 Cents   |
| No. of Floors                           | : Ground + 4   |
| Floor Area                              | : 3890 Sq.m  |
| Air conditioned Area                    | : 1758 Sq M  |
| No. of persons working                  | : 90 Persons   |
| Connected load                          | : 702 kW   |
| Contract demand                         | : 500kVA   |
| Recorded Maximum Demand                 | : 427kVA   |
| Average power Factor                    | : 0.967  |
| Building operating hours                | : 24 Hours   |
| Demand Factor                           | : 0.55   |
| Tariff                                  | : HT III   |
| Fixed Charge &Energy charge             | : 350/kVA & Rs 3.70/kVA  |
| Annual Energy Consumption (Electricity) | :27, 69,960 kWh  |
| Annual Electricity charges              | : Rs.1, 36, 30,684   |
| Annual Diesel consumption               | : 20,622 Ltrs  |
| Annual Diesel charges                   | : Rs.7, 21,770   |
| Total Annual Energy cost                | : Rs 14,352,454  |
| Major Equipments housed                 | : GSM-MSC1, GSM-MSC2, E10B and Digital<br>Transmission Equipment |

### Summary of Energy Saving Recommendations

| Sl. No.    | Energy Saving Recommendations   | Technical Target  | Annual Savings (Rs.) | Capital Investment (Rs.) | Simple Pay Back Period, (Months) | Return on Investment (%) | Internal Rate of Return (%) |
|------------|---|---|----------------------|--------------------------|----------------------------------|--------------------------|-----------------------------|
| <b>I</b>   | <b>Electrical Distribution Systems</b>  |   |                      |                          |                                  |                          |                             |
| 1          | Reduction in connected load   | Rationalization of CD                                       | 1,21,800             | NIL                      | NA                               | -                        | -                           |
| 2          | Improvement of Power Factor   | Reactive Power Management                                   | 95,700               | 35,000                   | 5                                | 260.57                   | Above 100                   |
| 3          | Replacement of over loaded cable for supply of AC Plants  | Reducing wastage of energy                                  | 63,385               | 32,200                   | 6                                | 196.85                   | Above 100                   |
| <b>II</b>  | <b>Exchange Equipment</b>   |   |                      |                          |                                  |                          |                             |
| 4          | Replacement of conventional type power plant with SMPS Power plant  | Adopting energy efficient technology to curtail consumption | 2,87,712             | 5,50,000                 | 23                               | 52.31                    | 47.45                       |
| <b>III</b> | <b>Lighting system</b>  |   |                      |                          |                                  |                          |                             |
| 5          | Replacement of light fittings with energy efficient fittings in corridors and Lobby.  | Induction of Energy efficient Technology                    | 1,24,869             | 49,449                   | 4                                | 277                      | Above 100                   |
| <b>IV</b>  | <b>Heating, Ventilation and Air-conditioning</b>  |   |                      |                          |                                  |                          |                             |
| 6          | Providing ceiling insulation to Motorola and Nortel equipment rooms   | Tapping available opportunity to cut Energy wastages.       | 2,78,603             | 1,49,061                 | 4                                | 186.91                   | Above 100                   |
| 7          | Re routing and Rearrangement of AC Plant and Providing partition of AC plant room and correction of Thermostat settings, Condenser stopping | Tapping available opportunity to cut Energy wastages.       | 2,82,831             | 2,64,725                 | 11.2                             | 106.8                    | Above 100                   |
| 8          | Providing Partition to Transmission room at Third Floor   | Tapping available opportunity to cut Energy wastages.       | 30,050               | 22,800                   | 9                                | 131.7                    | Above 100                   |
| 9          | Disconnection of life expired Low efficiency AC Units,  | Inducting efficient Technology to improve efficiency        | 1,41,344             | 58,925                   | 5                                | 239                      | Above 100                   |

| Sl. No.    | Energy Saving Recommendations   | Technical Target                                  | Annual Savings (Rs.) | Capital Investment (Rs.) | Simple Pay Back Period, (Months) | Return on Investment (%) | Internal Rate of Return (%) |
|------------|---|---|----------------------|--------------------------|----------------------------------|--------------------------|-----------------------------|
| <b>V</b>   | <b>Diesel Generator Sets</b>  |   |                      |                          |                                  |                          |                             |
| 10         | Improving the efficiency of 500 KVA EA set  | Improving Efficiency                              | 44,170               | 55,000                   | 15                               | 80.3                     | 78.49                       |
| <b>VI</b>  | <b>Water Pumps</b>  |   |                      |                          |                                  |                          |                             |
| 11         | Replacement of life expired pump and delivery pipe                                | Enhancing Energy Efficiency                       | 20,967               | 28,000                   | 16                               | 74.8                     | 72.77                       |
| <b>VII</b> | <b>Renewable Energy sources</b>   |   |                      |                          |                                  |                          |                             |
| 12         | Replacement of heaters with solar water heaters and installation of Bio-Gas Plant | Tapping solar power under National solar Missions | 20,004               | 39,500                   | 30                               | 38.9                     | 31.51                       |
|            | <b>Total</b>  |   | 15,11,435            | 12,84,660                | 10.2                             |                          |                             |

## 5.14. Telephone Exchange Building, Medical College, Thiruvananthapuram

Audited by: BSNL, Thiruvananthapuram

The very nature of the operations of a TE building that functions round the clock provides excellent opportunity to conserve energy. A small measure in one Energy intensive system can bring about a large quantity of savings, which make such measures very attractive as well.

### Summary of Energy Saving Recommendations

| Sl.No      | Energy saving Recommendations  | Technical Target  | Annual savings in Rs (Lakh) | Capital investment in Rs (Lakh) | Simple payback period in (years) | Return on Investment (%) | Internal Rate of return (%) |
|------------|--|---|-----------------------------|---------------------------------|----------------------------------|--------------------------|-----------------------------|
| <b>I</b>   | <b>Electrical Distribution System</b>  |   |                             |                                 |                                  |                          |                             |
| 1          | Use of LED type Indication lamps in LT Panels  | Enhancing energy efficiency   | 0.2                         | 0.098                           | 0.43                             | 233.4                    | 233                         |
| <b>II</b>  | <b>Lighting System</b>   |   |                             |                                 |                                  |                          |                             |
| 2          | Replacement of 2x40w fluorescent fittings with 2 x 28 w Box T5 Fittings                | Induction of energy efficient technology  | 1.9                         | 4.7                             | 2.5                              | 40.4                     | 32                          |
| 3          | Replacement of GLS/Fl. Fittings with 11 WCFL   | Induction of energy efficient technology  | 0.04                        | 0.08                            | 1.9                              | 53.0                     | 39                          |
| <b>III</b> | <b>HVAC System</b>   |   |                             |                                 |                                  |                          |                             |
| 4          | Providing inter locks to stop condensers with compressors                              | Tapping available opportunity to cut energy wastage                               | 0.28                        | 0.20                            | 0.7                              | 139.1                    | 138                         |
| 5          | Replacing of life expired AC units in RRC with reduction in No. of units               | Inducting efficient technology to improve efficiency and to reduce energy wastage | 1.16                        | 1.40                            | 1.2                              | 83.1                     | 77                          |
| 6          | Replacement of in efficient and life expired WAC/SAC units                             | Inducting efficient technology to improve efficiency                              | 1.50                        | 2.00                            | 1.3                              | 75.1                     | 70                          |
| 7          | Replacement of resistance type regulators with energy efficient Electronic regulators. | Adopting energy efficient technology to curtail wastage                           | 0.06                        | 0.09                            | 1.6                              | 62.16                    | 55                          |



| Sl.No     | Energy saving Recommendations   | Technical Target  | Annual savings in Rs (Lakh) | Capital investment in Rs (Lakh) | Simple payback period in (years) | Return on Investment (%) | Internal Rate of return (%) |
|-----------|---|---|-----------------------------|---------------------------------|----------------------------------|--------------------------|-----------------------------|
| <b>IV</b> | <b>Pumping System</b>   |   |                             |                                 |                                  |                          |                             |
| 8         | Replacement of 1No 10HP centrifugal pump set by energy efficient submersible pump set | Deriving optimum efficiency through better design, where Replacement is already due | 0.12                        | 0.35                            | 3.0                              | 33.6                     | 27                          |
| <b>V</b>  | <b>Energy Monitoring</b>  |   |                             |                                 |                                  |                          |                             |
| 9         | Providing individual Energy meters for Major Loads                                    | Effective Energy monitoring and improved energy management                          | 2.82                        | 1.03                            | 0.4                              | 274.1                    | 275                         |
| <b>VI</b> | <b>Renewable Energy Measures</b>  |   |                             |                                 |                                  |                          |                             |
| 10        | Providing Solar water heater system to Replace coil heaters & geysers                 | Tapping Solar power under National solar mission                                    | 0.13                        | 0.40                            | 3.0                              | 33.2                     | 26                          |
| 11        | Providing rain water harvesting system  | Tapping of bountiful rainwater.   | 0.30                        | 0.30                            | 1.0                              | 99.4                     | 97                          |
|           | <b>Total</b>  |   | 8.51                        | 10.65                           | 1.25                             |                          |                             |

## 5.15. Vikas Bhawan, Thiruvananthapuram

Audited by: FICCI, New Delhi

Vikash Bhawan has a connected load of around 360 kW (As per Inventory Survey). As per electricity bills, the electrical energy consumption stands at about 20000 kWh per month i.e. about 1.35 Lakh Rs. per month. The detail energy audit reveals that various energy conservation and efficiency options can further result in saving of about Rs. 11 lakh per annum and reduce the energy consumption by 1.4 lakh units per annum (About 58% of the total consumption). The summary of the potential savings has been shown in the following table.

### Summary of Potential Saving

| SN           | Area                           | Recommendations  | Expected Benefit/Saving                                   | Approx. Investment (Lakh Rs.) | Simple Pay Back Period (Years) |
|--------------|--------------------------------|--|---|-------------------------------|--------------------------------|
| 1            | Electrical Distribution System | Reviewing the tariff structure of Meter # 3584 with KSEB Authority                     | 3.3 Lakh Rs./annum  | -                             | -                              |
| 2            | Electrical Distribution System | Installation of 60 KVAR (3x20) capacitor banks at LT main Panel of CD block & EF block | PF improvement to 0.99<br>Reducing the Demand by 20 kVA   | 1.2                           | NA                             |
| 3            | Lighting System                | Replacing main LT panels with New Panels   | Reliability in Power Supply<br>Reduction in safety Hazard | 4.0                           | NA                             |
| 4            | Lighting System                | Retrofitting the FTLs with 18W CFLs in Non-Essential Areas                             | 16,416 kWh /annum<br>0.93 Lakh Rs./annum                  | 0.5                           | 0.54                           |
|              |                                | Retrofitting the FTLs with T5 Lamps in essential Areas                                 | 93,607 kWh /annum<br>5.3 Lakh Rs./annum                   | 7.6                           | 1.4                            |
| 5            | Comfort AC System (Window AC ) | Replacing the old units with BEE star rated AC units                                   | 23,772 kWh/annum<br>1.2 Lakh Rs./annum                    | 3.5                           | 1.2                            |
|              |                                | Installation of Auto ON/OFF actuator switch and water level indicator                  | 3,000 kWh/annum<br>0.17 Lakh Rs./annum                    | 0.10                          | 1.2                            |
| 6            | Water Pumping System           | Replacing the existing 5hp pumps with energy efficient pumps of same capacity          | 2,997 kWh/annum<br>0.17 Lakh Rs./annum                    | 0.2                           |                                |
|              |                                | Providing Electronic Energy Meters & Run-Hour Meters for each pump                     | Better Energy Monitoring & Accounting                     | 0.1                           |                                |
| 7            | Others                         | Providing Electronic Energy Meters at Strategic Locations                              | Better Energy Monitoring & Accounting                     | 0.3                           |                                |
| <b>TOTAL</b> |                                |  | 1,39,792 kWh/annum  | 17.5                          | 1.58                           |
|              |                                |  | 11.07 Lakh Rs./annum                                      |                               |                                |

## 5.16. Civil Station, Kozhikode

Audited by: BSNL, Thiruvananthapuram

The Civil Station building is the most important Public Building in Calicut District. This Building Complex houses 35 departmental offices of the state government, including offices of District Collector, District Medical officer, District Labour officer, Principal Agricultural officer, offices of Public Works Department, Excise Dept etc. The Building complex forms the nerve center of District Administration and thousands of people from various parts of Calicut District visit this building complex for satisfying their needs. Hence, the Energy Conservation/Environmental Protection activities launched in this complex will attract large public attention and can act as a catalyst for creating awareness among General Public.

### Summary of Energy Saving Recommendations

| Sl.No | Energy saving Recommendations  | Technical Targets                            | Annual savings in (Lakh) | Capital investment in (Lakh) | Simple pay back period in Months | Return on Investment (%) | Internal Rate of return (%) |
|-------|--|--|--------------------------|------------------------------|----------------------------------|--------------------------|-----------------------------|
| I     | <b>Electrical Distribution System</b>  |  |                          |                              |                                  |                          |                             |
| 1     | Balance of unbalanced load in cables and panels. (Excessive neutral current)   | Reducing wastage of Energy                   | 0.01                     | 00                           | 00                               | 100                      | Full                        |
| 2     | Removal of earth leakage in panels and cables  | Reducing wastage of Energy                   | 0.23                     | 00                           | 00                               | 100                      | Full                        |
| 3     | Providing Automatic power factor correction panel with 150 kVAR capacitor bank to bring the power factor from 0.8 to unity   | Enhancing Energy Efficiency                  | 0.97                     | 2.5                          | 31                               | 39                       | 31.36                       |
| II    | <b>Lighting System</b>   |  |                          |                              |                                  |                          |                             |
| 4     | Replacement of 417 no's of 2 x 40 w fluorescent fittings and 885 numbers of 1 x 40 w light fittings fluorescent fittings with 1 x 28/2 x 28 w T5 Fittings                  | Tapping New Technology for Energy efficiency | 2.53                     | 10.34                        | 49                               | 25                       | 12.23                       |
| 5     | Replacement of high energy consuming conventional fans with energy efficient fans & energy wasting resistance type regulators with energy efficient electronic regulators. | Tapping New Technology for Energy efficiency | 2.34                     | 6.53                         | 34                               | 36                       | 27.82                       |
| 6     | Replacement of incandescent lamp with 11w CFL  | Tapping New Technology for Energy efficiency | 0.50                     | 0.32                         | 7.6                              | 64                       | 57.1                        |
| III   | <b>HVAC System</b>   |  |                          |                              |                                  |                          |                             |

|              |   |   |                                 |                                     |   |                                 |                                    |
|--------------|---|---|---------------------------------|-------------------------------------|---|---------------------------------|------------------------------------|
| 7            | Realignment/repositioning 10 numbers of SAC unit condensers at E/E1 block for energy efficient operation of the AC unit   | Enhancing Energy Efficiency                             | 0.30                            | 0.30                                | 12                                      | 100                             | 98.70                              |
| <b>Sl.No</b> | <b>Energy saving Recommendations</b>  | <b>Technical Targets</b>                                | <b>Annual savings in (Lakh)</b> | <b>Capital investment in (Lakh)</b> | <b>Simple pay back period in Months</b> | <b>Return on Investment (%)</b> | <b>Internal Rate of return (%)</b> |
| 8            | Refrigerant gas topping up for 2 numbers of WAC units, which are inefficient due to shortage of gas.  | Enhancing Energy Efficiency                             | 0.062                           | 0.014                               | 3                                       | 450                             | Above 100                          |
| 9            | Replacement of in efficient and life expired WAC units, one each in Treasury Server room and RTO office with energy efficient SAC units   | Enhancing Energy Efficiency                             | 0.25                            | 0.44                                | 21                                      | 57                              | 52.98                              |
| <b>IV</b>    | <b>Pumping System</b>   |   |                                 |                                     |   |                                 |                                    |
| 10           | Replacement of 1No conventional centrifugal pump set for D block with an energy efficient submersible pump set and repairing of existing bore well pump sets for utilization of existing open/bore wells. | Tapping New technology for Energy efficiency            | 2.52                            | 0.42                                | 2                                       | 600                             | Above 100                          |
| 11           | Installation of Water Level controller to prevent loss of water and energy due to over flow in tanks  | Better management of Water energy                       | 0.079                           | 0.60                                | 91                                      | 13.16                           | 3.2                                |
| <b>V</b>     | <b>Energy Monitoring and Accounting System</b>  |   |                                 |                                     |   |                                 |                                    |
| 12           | Installation of separate energy meter for individual departments to avoid penalty for delayed payment and to make departments accountable   | Better management of Energy consumption                 | 6.58                            | 4.1                                 | 8                                       | 160                             | Above 100                          |
| <b>VI</b>    | <b>Other Renewable Energy Conservation Measures</b>   |   |                                 |                                     |   |                                 |                                    |
| 13           | Providing Bio Gas Plant (25 M <sup>3</sup> ) for utilization of biomass energy and to arrest environmental degradation.   | Environmental protection coupled with Energy efficiency | 1.26                            | 3.5                                 | 33                                      | 36                              | 28.15                              |
| 14           | Solar Water Heater (800 LPD) for canteens to utilize solar power and to reduce carbon dioxide emission by burning of wood   | Tapping natural resources for selected Energy needs     | 0.54                            | 1.38                                | 31                                      | 39.25                           | 31.98                              |


|    |  |   |        |        |    |    |       |
|----|--|---|--------|--------|----|----|-------|
| 15 | Tapping rain water from existing rain water harvesting tanks for daily use | Tapping natural resources for Sustainable habitat | 0.012  | 0.02   | 20 | 60 | 57.30 |
|    | <b>TOTAL</b>   |   | 18.183 | 30.464 | 20 |    |       |

## 5.17. Government Medical College Hospital, Kozhikode

Audited by : Eaga Energy Pvt Ltd, Kolkatta

GMC has forty two (42) connections, of which one 11kV HT connection and another six 11 kV deemed HT connection for the medical college, the rest are LT connections. The total electricity consumption from November, 2007 to December, 2008 is 7, 66,024 kWh and the electricity cost during the same period is Rs. 41.96 lakh. The major energy consuming equipments of the complex are:

- Lighting
- Individual AC units
- Ceiling fans
- Pumps
- Street lighting
- Computers and printers



### Summary of Energy Saving Recommendations

| S. No    | Recommendation  | Saving potential / Year |           | Capital investment (Rs Lakh) | Simple payback period (Years) |
|----------|---|-------------------------|-----------|------------------------------|-------------------------------|
|          |   | kWh                     | Rs. Lakh  |                              |                               |
| 1        | Replacement of conventional FTLs with T 5 lights                      | 2, 54,050               | 12.7      | 20                           | 1.6                           |
| 2        | Replacement of GLS lamps by 22 W CFLs                                 | 1,14,000                | 5.7       | 1.5                          | 0.3                           |
| 3        | Energy improvement in Street lighting                                 | 30,782                  | 1.53      | 0.78                         | 0.5                           |
| 4        | Replacement of existing water pumps by new efficient pumps            | 98,550                  | 4.9       | 0.55                         | 0.1                           |
| 5        | Purchase of cleaning blower for air conditioners                      | 24,000                  | 1.2       | 0.50                         | 0.25                          |
| 6        | New temperature feedback control to Replace the old fittings          | 65,000                  | 3.25      | 2.0                          | 0.6                           |
| 7        | Replacement of conventional fan regulators with electronic regulators | 50,000                  | 2.5       | 2.65                         | 1.1                           |
| <b>8</b> | <b>Total</b>  | <b>6, 36,382</b>        | <b>32</b> | <b>28</b>                    | <b>0.9</b>                    |

## 5.18. Kerala Financial Corporation, Ernakulam

Audited by: Eaga Energy Pvt Ltd, Kolkatta

Kerala Financial Corporation (KFC) incorporated under the State Financial Corporations Act of 1951, is a trend setter and path breaker in the field of long term finance, playing a major role in the development and industrialization of Kerala. It was established as the Travancore Cochin Financial Corporation on 01.12.1953. Consequent to the reorganization of states on linguistic basis in November 1956, Kerala State was formed and the Travancore Cochin Financial Corporation was renamed as Kerala Financial Corporation.

Now KFC has 16 Branch Offices with its Head Quarters at Thiruvananthapuram and Zonal Offices at Kozhikode, Ernakulam and Thiruvananthapuram.

### Summary of Energy Saving Recommendations

| SL | Recommendations                                  | Saving Potential / Yrs |       | Capital Investment (Rs) | Simple Payback Period (Years) |
|----|--|------------------------|-------|-------------------------|-------------------------------|
|    |  | kWh                    | Rs    |                         |                               |
| 1  | Replacement of conventional FTLs with T 5 lights | 20,516                 | 1.13  | 2.23                    | 2                             |
| 2  | Replacement of GLS lamps by 11 W CFLs            | 2,111                  | 0.11  | 0.035                   | 0.3                           |
| 3  | Lighting transformer                             | 4,500                  | 0.225 | 0.45                    | 2                             |
|    | <b>Total</b>                                     | 28,096                 | 1.525 | 2.746                   | 1.8                           |

GHG emission reduction that will result from energy saving opportunities identified by the study is estimated to be 28 tCO<sub>2</sub>e per annum.

## 5.19. College of Engineering, Thiruvananthapuram

Audited by: Eaga Energy Pvt Ltd, Kolkatta

The College of Engineering, Thiruvananthapuram was established in 1939 as the first Engineering College in the then Travancore State. The institution owes its foundation to the bold and inspired vision of Sree Chithira Thirunal Balarama Varma, the then Maharaja of Travancore. The College was shifted to the present sprawling 45 hectares campus in 1960.

### Summary of Energy Saving Recommendations

| S. No | Recommendation  | Saving potential / Year |          |    | Capital investment (Rs. Lakh) | Simple payback period (Years) | ROI (%) | CO <sub>2</sub> emission Reduction/ Year |
|-------|---|-------------------------|----------|----|-------------------------------|-------------------------------|---------|--|
|       |   | kWh                     | Rs. Lakh | %  |                               |                               |         |  |
| 1     | Demand side management  | NA                      | 1.62     | NA | 0.50                          | 0.33                          | 314     | --                                       |
| 2     | Replacement of conventional FTLs with T 5 lights                      | 60,000                  | 3.3      | 44 | 13.2                          | 4                             | 5       | 51 T                                     |
| 3     | Replacement of GLS lamps by 11 W CFLs                                 | 32,700                  | 1.8      | 70 | 1.12                          | 0.62                          | 135.7   | 27.8 T                                   |
| 4     | Replacement of HPMV lamps by MH lamps                                 | 30,700                  | 1.69     | 36 | 2.24                          | 1.3                           | 50.4    | 26.1 T                                   |
| 5     | Replacement of existing water pumps by new efficient pumps            | 5,000                   | 0.275    | 42 | 0.72                          | 2.62                          | 25.7    | 4.2 T                                    |
| 6     | Purchase of cleaning blower for air conditioners                      | 36,000                  | 2        | 5  | 0.50                          | 0.25                          | 375     | 30.6 T                                   |
| 7     | Intelligent control for old stand alone AC                            | 35,000                  | 1.90     | 10 | 0.90                          | 0.5                           | 186     | 29.75 T                                  |
| 8     | Replacement of conventional fan regulators with electronic regulators | 22,500                  | 1.23     | 15 | 1.88                          | 1.5                           | 40.4    | 19 T                                     |
|       | <b>Total</b>  | 2,21,900                | 13.81    |    | 21.06                         | 1.53                          |         | 188.45 T                                 |

| Classification of Investment |                 |                       |                    |
|------------------------------|-----------------|-----------------------|--------------------|
| Scale on investment          | Number of items | % energy saving in Rs | % investment in Rs |
| Low investment (< 5 lakh)    | 7               | 76                    | 37                 |
| Medium investment (<10 lakh) | 0               | 0                     | 0                  |
| High investment (>10 lakh)   | 1               | 24                    | 63                 |

GHG emission reduction that will result from energy saving opportunities identified by the study is estimated to be 188.45 tCO<sub>2</sub>e per annum.



## 5.20. Civil Station, Thrissur

Audited by: Eaga Energy Pvt Ltd, Kolkatta

The Civil Station in Thrissur houses multiple government offices including the district court, district police head quarter, district collector's office etc.

### Summary of Energy Saving Recommendations

| SL | Recommendations   | Saving Potential / Yrs |           | Capital Investment (Rs) | Simple Payback Period (Years) |
|----|---|------------------------|-----------|-------------------------|-------------------------------|
|    |   | kWh                    | Rs        |                         |                               |
| 1  | Replacement of conventional FTLs with T 5 lights                      | 8,395                  | 46,172    | 100,000                 | 2.16                          |
| 2  | Replacement of GLS lamps by 11 W CFLs                                 | 11,088                 | 60,984    | 16,500                  | 0.27                          |
| 3  | Replacement of HPSV lamps by LPSV lamps                               | 4,334                  | 23,837    | 11,000                  | 0.5                           |
| 4  | Replacement of existing water pumps by new efficient pumps            | 3,660                  | 20,130    | 35,000                  | 1.73                          |
| 5  | Timer based controller for air conditioners                           | 7,200                  | 39,600    | 33,600                  | 0.80                          |
| 6  | Replacement of conventional fan regulators with electronic regulators | 6,000                  | 33,000    | 80,160                  | 2.43                          |
|    | <b>Total</b>  | 40,677                 | 2, 23,723 | 2, 76,260               | 1.23                          |

## 5.21. Civil Station, Ernakulam

Audited by: FICCI, New Delhi

Civil Station, the office of the district collector of Ernakulam is located at the outskirts of the Cochin city. The building established about 25 years back is a multi-storied building with total of six floors. About 500 employees are working in this office with office hour of 8 hours in week days and Saturday.

The Assistant Executive Engineer (Electrical) of PWD looks after the management of electric supply, water supply, ventilation & air conditioning, lighting system etc. of the entire building to ensure proper work environment and comfort of its employees. As explained earlier, the energy conservation has become a foremost requirement in any high rising building which has a connected load of 500 kW and more, the Civil Station is also no exception.

Civil Station has a connected load of around 165 kW (As per Inventory Survey). As per electricity bills, the electrical energy consumption stands at about 26900 kWh per month i.e. about 1.82 Lakh Rs. per month.

The detail energy audit reveals that various energy conservation and efficiency options can further result in saving of about Rs.4.14 lakh per annum and reduce the energy consumption by 0.62 lakh units per annum (About 19% of the total consumption). The summary of the potential savings has been shown in the following table.

### Summary of Energy Saving Recommendations

| SN | Area                           | Recommendations  | Expected Benefit  | Approx. Investment (Lakh Rs.) | Simple Pay Back Period (years) |
|----|--------------------------------|--|---|-------------------------------|--------------------------------|
| 1  | Electrical Distribution System | Replacing the LT panel of Switch Room#2  | Reliability in Power Supply<br>Reduction in Safety Hazard | 1.0                           | -                              |
| 2  | Electrical Distribution System | Installation of 80 kVAR (4x20) capacitor banks at LT main Panels                         | PF improvement to 0.99<br>Reducing the Demand by 30 kVA   | 0.8                           | NA                             |
| 3  | Lighting System                | Retrofitting the FTLs with 18W CFLs in Non-Essential Areas                               | 12,240 kWh /annum<br>0.83 Lakh Rs./annum                  | 0.35                          | 0.43                           |
|    |                                | Retrofitting the FTLs with T5 Lamps in essential Areas and rearrangement of FTL fittings | 37,200 kWh/annum<br>2.52 Lakh Rs./annum                   | 3.22                          | 1.3                            |
|    |                                | Installation of Solar Powered lights for Campus area                                     | 7,300 kWh/annum<br>0.5 Lakh Rs./annum                     | 2.5                           | 5.0                            |

| SN | Area                 | Recommendations   | Expected Benefit                        | Approx. Investment (Lakh Rs.) | Simple Pay Back Period (years) |
|----|----------------------|---|---|-------------------------------|--------------------------------|
| 4  | Water Pumping System | Installation of Auto ON/OFF actuator switch and water level indicator                             | 3,000 kWh/annum<br>0.17 Lakh Rs./annum  | 0.10                          | 1.2                            |
|    |                      | Replacing the existing 7.5 hp pumps with energy efficient pumps of same capacity at A1 side block | 1,772 kWh/annum<br>0.12 Lakh Rs./annum  |                               |                                |
|    |                      | Providing Electronic Energy Meters & Run-Hour Meters for each pump                                | Better Energy Monitoring & Accounting   | 0.1                           |                                |
|    | <b>TOTAL</b>         |   | 61,512 kWh/annum<br>4.14 Lakh Rs./annum | 8.27                          | 2                              |

## 5.22. High Court Building, Ernakulam

Audited by: BSNL, Thiruvananthapuram

On the integration of Travancore - Cochin State after independence on 1<sup>st</sup> July 1949, it was on the 7<sup>th</sup> of July 1949 that the High Court of Travancore-Cochin was inaugurated with its seat at Ernakulam. High Court of Kerala came into being from 1<sup>st</sup> November 1956, with its seat at Ernakulam. The High Court of Kerala has jurisdiction over the Subordinate Courts and the Tribunals in the State of Kerala and the Union Territory of Lakshadweep, where it is the highest judicial forum. The High Court transacts its judicial functions, the Judges sitting in Single, in Division Bench and in specifically referred cases in Full Bench and also in Larger Bench.

The High Court is functioning in the new 8 storied building since 2006. The building is located on the shores of Vembanad Lake, close to Marine Drive. The building is having 11 blocks with a total built up area of 52,280 Sq.m. This massive edifice has many special environmental friendly features, most significant of which is the twin court yard (Quadrangle), around which various blocks are built up. The airy and naturally lighted wide corridors, facing the twin quadrangle, are the life lines of the building. These corridors, by its sheer concept, makes every moment of the occupant of the space fairly comfortable, with least demand on energy. They exude warmth and provide a sense of security and comfort to the occupant, while one is on the move or in waiting for one's work in 30 court halls, 36 Chambers and administrative offices, all of which are housed in a well spread out manner in this building. This building complex also accommodates Advocate General's office, National Informatics Centre, Bank, Post Office, Dispensary etc. There are 1500 employees working in the High Court to take care of the judicial needs of the State's public, through 30 Hon: Justices and 5000 advocates, for who all this wonderful edifice plays host.

|                                     |                         |
|-------------------------------------|-------------------------|
| Annual Electricity consumption (Av) | : 15, 99,070 kWh        |
| Annual Electricity Charges          | : Rs 92.08 Lakh         |
| Annual Diesel Consumption (DG Set)  | : 5,196 liters (Approx) |
| Annual Fuel (HSD) Charges           | : Rs. 1, 97,448/-       |
| Annual Water Consumption            | : 18,000 Kilo liters    |
| Annual Water Charges                | : Rs. 2, 70,000/-       |
| Annual LPG consumption              | : 11,520 Kg             |

## Summary of Energy Saving Recommendations

| Sl. No     | Energy Saving Recommendations at a Glance   | Technical target  | Annual Energy Saving kWh | Annual Cost Savings (Rs.) | Capital Investment (Rs.) | Simple Pay Back period | ROI (%) | IRR (%) |
|------------|---|---|--------------------------|---------------------------|--------------------------|------------------------|---------|---------|
| <b>I</b>   | <b>Electrical Distribution System</b>   |   |                          |                           |                          |                        |         |         |
| 1          | Load Balancing to reduce the neutral current and cleaning and tightening of terminals   | Reducing Wastage of Energy                                  | 15,991 kWh               | 42,881                    | 3500                     | 1 month                | Full    | FULL    |
| 2          | Servicing of APFC Controller, panel and Replacement of capacitors to increase PF from 0.926 to 0.98                               | Reactive Power management                                   | NA                       | 1,80,624                  | 71,000                   | 4 months               | 254     | 286     |
| <b>II</b>  | <b>Lighting System</b>  |   |                          |                           |                          |                        |         |         |
| 1          | Use of LED lamps for aviation lamp in place of incandescent lamps   | Enhancing Energy Efficiency                                 | 1,037 kWh                | 4,044                     | 20,000                   | 5 years                | 20      | 8       |
| 2          | Use of Natural light, and implementing ENCON options 4,5,6 under LIGHTING   | Tapping natural resources, sustainable habitat              | 9,360 kWh                | 28,080                    | NIL                      | NA                     | NA      | NA      |
| <b>III</b> | <b>Air-Conditioning System</b>  |   |                          |                           |                          |                        |         |         |
| 1          | Cleaning of dirty condenser, evaporator, filters, Replacement of capacitors, topping up R-22etc                                   | Improving efficiency thru better maintenance practices      | 22,680 kWh               | 79,380                    | NIL                      | NIL                    | NIL     | NIL     |
| 2          | Providing Door closures in conditioned rooms  | Enhancing Energy Efficiency                                 | 6,720 kWh                | 23,250                    | 30,000                   | 1.3 years              | 78.4    | 65      |
| 3          | Providing alternative/ standby AC system to substitute stand-alone operation of existing 50 TR Chiller plant.                     | Improving Energy efficiency thru better operation practices | 65,850 kWh               | 2,30,475                  | 2,30,000                 | 1 year                 | 100     | 113     |
| 4          | Split A/C Units Replacing faulty Starting / Running Capacitors, Topping up of Refrigerant Gas, Cleaning of Fins                   | Improving efficiency thru better maintenance practices      | 10,765 kWh               | 71,294                    | 12,000                   | 2 months               | 594     | 628     |
| 5          | Closure of Chiller piping valves of non operating units, when the respective AHUs are in OFF condition.                           | Improving Energy efficiency thru better operation practices | 3,192 kWh                | 10,640                    | NIL                      | NA                     | NA      | NA      |
| 6          | Arrest leakages of chilled water through Glands and proper chiller line insulation on damaged portion of chilled water pipe lines | Improving efficiency thru better maintenance practices      | 19,141 kWh               | 57,422                    | 5,000                    | 1 month                | Full    | FULL    |

| Sl. No                                      | Energy Saving Recommendations at a Glance   | Technical target  | Annual Energy Saving kWh | Annual Cost Savings (Rs.) | Capital Investment (Rs.) | Simple Pay Back period | ROI % | IRR % |
|---|---|---|--------------------------|---------------------------|--------------------------|------------------------|-------|-------|
| <b>IV Pumping system</b>                    |   |   |                          |                           |                          |                        |       |       |
| 1   | Replacing existing centrifugal Pump with submersible Pump for fresh water arrangement   | Improving Energy efficiency                                 | 7,854 kWh                | 30,489                    | 38,000                   | 1.2 years              | 80    | 84    |
| 2   | Replacing existing centrifugal Pump with submersible Pump for Flush water arrangement   | Improving Energy efficiency                                 | 3,343 kWh                | 14,701                    | 67,000                   | 4.6 years              | 22    | 24    |
| <b>V Lift</b>                               |   |   |                          |                           |                          |                        |       |       |
| 1   | Savings on account of switching of one lift in each section, except Judges, during Peak hours                                   | Improving Energy efficiency thru better operation practices | 5,513 kWh                | 16,539                    | NIL                      | NA                     | NA    | NA    |
| 2   | Savings on account of encouraging usage of staircase to travel one or two floors up and down                                    |   | 2,804 kWh                | 8,412                     | NIL                      | NA                     | NA    | NA    |
| <b>VI Energy Monitoring &amp; Targeting</b> |   |   |                          |                           |                          |                        |       |       |
| 1   | Providing Energy Meters floor or section wise for effective monitoring of Energy consumption and creating awareness among staff | Energy monitoring and Targeting                             | 15,990 kWh               | 92,000                    | 35,500                   | 5 months               | 259   | 259   |
| <b>VII Tapping Renewable Sources</b>        |   |   |                          |                           |                          |                        |       |       |
| 1   | Providing Solar Water heaters of 500 Ltrs capacity for Canteen  | Tapping natural resources to meet part demand               | 1,060 KG LPG             | 25,683                    | 1, 11,000                | 4.3 years              | 23    | 10.8  |
| 2   | Bio Gas Plant ((20M <sup>3</sup> ) for utilization of biomass.  | Tapping Renewable energy from bio waste                     | 1,470 KG LPG             | 1,00,240                  | 2,45,000                 | 2.4 years              | 41    | 54    |
|   | <b>Total</b>  |   | 1,90,240 kWh             | 10,16,154                 | 8,68,000                 | 0.85 years             |       |       |
| <b>VIII Optional items</b>                  |   |   |                          |                           |                          |                        |       |       |
| 1   | Replacement of CRT Monitors with LCD or TWT Monitors  | Enhancing Energy Efficiency                                 | 19,305 kWh               | 84,034                    | 6,60,000                 | 7.9 years              | 12.7  | 11.7  |
| 2   | Providing Roof top Rain Water Harvesting  | Tapping natural resources to meet part demand               | 6,750 Kilo ltrs          | 91,125                    | 10, 00,000               | 11 years               | 9     | 10.8  |
| 3   | Providing 5 KW Solar-Wind Hybrid system to utilize natural resources  | Tapping renewable energy from Sun and wind                  | 19,320 kWh               | 67,620                    | 23,00,000                | Very high              | LOW   | LOW   |
|   | <b>Total of Optional Items</b>  |   | 38625 kWh                | 2,42,779                  | 39,60,000                | 16.3 years             |       |       |
|   | <b>Grand Total</b>  |   | 2,28,865kWh              | 12,58,933                 | 48,28,000                | 3.83 years             |       |       |

## 6. IGEA Consultative Meeting- Highlight

An IGEA consultative meeting was held on 13<sup>th</sup> November 2009 after the receipt of all the Energy Audit reports. Various stakeholders in building energy efficiency and senior officials from the State and Central government as well as financial institutions participated in the meeting. This meeting was convened to discuss on implementation of audit findings and the ESCO mode of Implementation. This was to facilitate the building owners to clarify any queries on the energy audit undertaken.

The meeting provided an interactive platform for the audit firms, the consultants as well as the building owners. All building owners except Shaktan Thampuram Arcade owner participated in the programme. The meeting was attended by all the energy auditors who undertook the IGEA.

A detailed session on ESCO concepts and various modalities of implementation in ESCO route was handled by EMC invited consultant Mr Pradeepkumar, Alliance to Save Energy, Bangalore. He explained the concept of ESCO, the necessity, the implementation methodologies or modes as well as the contract requirement for the same.

The session was inaugurated by Mr L Radhakrishnan, IAS, Principal Secretary (Power). He applauded EMC initiative to start such a dialogue between the building owners and the contractors. He stated that, the implementation of these measures should be taken up on a priority basis so that these government buildings act as demonstrative projects to the other sectors as well as the public to follow. The Principal Secretary mentioned that a similar training programme needs to be initiated with the Public Works Department. He also mentioned during the course of the training that an ESCO model implementation would facilitate the building owners to undertake such projects without allocating funds from their revenue. The process of implementation can be swifter without using the public money. He actively participated in the deliberations.

The Key Note Address by Mr. K M Dhaharan Unnithan, Director, EMC covered the salient features in the audits undertaken. The key shortcomings in the audits were also covered in the address. The Presentation on IGEA (Investment Grade Energy Audit) covered the Bureau of Energy Efficiency Programme in Government Buildings. The EMC as an SDA identified 22 Government Buildings and undertook the audit through the BEE listed ESCOs and Consultants. The presentation by Mr A M Narayanan, Head of the Energy Efficiency Division, EMC took the participants/ delegates through the scope of IGEA in an elaborate manner and opened the forum for the presentations by energy audit firms.





## The Welcome

A Brief Welcome for the dignitaries on and off the dais was delivered by Shri A M Narayanan, Head Energy Efficiency Division, EMC

## The Key Note Address

The Key Note Address by Shri K. M. Dharsan Unnithan, Director, EMC



## The Inaugural Address

The Inaugural Address by Shri L.Radhakrishnan, IAS, Principal Secretary Power, EMC



## The Audience for Audit Presentations



## ESCO Mode of Implementation

Shri Pradeepkumar, Alliance to Save Energy  
presenting his talk on ESCOs

## The Key Inferences generated

- The Building owners actively participated in discussions of the audit findings.
- One of the major inferences which were generated during the meeting was at least 50% of the audit undertaken are not compliant to Investment Grade Energy Audit but rather to an extended walk through audit. Some of the building owners passed on their concern on the lack of information on the implementation possibility.
- Enquires were generated on the ESCO mode of Implementation and two building owners are seriously considering this mode of implementation. The meeting was able to generate interest and commitment from the building owners for the implementation of the measures suggested by IGEA.
- Quality enhancement of the IGEA was requested by many of the building owners and the contractors have promised to deliver the same.
- PWD expressed interest in the implementation of the measures in the buildings maintained by them through their own resources.
- High Court Complex expressed interest in ESCO concept.

A brief Outline of general interest expressed by the building owners in implementation of the IGEA findings.

| <b>Expressed Interest in ESCO mode of Implementation</b> | <b>Implementation by own resources</b>                         | <b>Implementation by PWD</b>                            |
|--|--|---|
| High Court Building, Ernakulam                           | State Bank of Travancore , Thiruvananthapuram                  | Government Medical College Hospital, Thiruvananthapuram |
| Finance Towers, Kerala Financial Corporation, Ernakulam  | Mascot Hotel, KTDC, Thiruvananthapuram                         | Kerala Legislature Complex, Thiruvananthapuram          |
|  | The Kerala State Planning Board, Thiruvananthapuram            | Kerala Secretariat Complex, Thiruvananthapuram          |
|  | General Post Office Building, Thiruvananthapuram               | Vikas Bhawan, Thiruvananthapuram                        |
|  | BSNL–The Panampilly Nagar Telephone Exchange, Ernakulam        | Civil Station, Ernakulam                                |
|  | Telecom Exchange Building, Medical College, Thiruvananthapuram | Government Medical College, Kozhikode                   |
|  | Regional Cancer Centre, Thiruvananthapuram                     | Civil Station, Thrissur                                 |
|  | Vydyuthi Bhawan , Thiruvananthapuram                           | Civil Station, Kozhikode                                |
|  | Rajiv Gandhi Centre of Biotechnology, Thiruvananthapuram       | College of Engineering, Thiruvananthapuram              |
|  | Mail Business Centre, Thiruvananthapuram                       |   |

## **7. Conclusion**

A multitude of actions are necessary to aggressively reduce energy consumption in new and existing buildings. The Investment Grade Energy Audit is the first step towards the government's commitment of establishing energy efficiency norms for all its buildings.

Energy Management Centre is working towards engaging the various departments who are directly or indirectly involved in the implementation of the IGEA findings as well as the construction of new buildings in the state. The consultants who have undertaken IGEA are also expected and are willing to provide implementation support to the building owners. The IGEA Implementation Consultative Meeting on November 13<sup>th</sup> 2010 brought together all the stakeholders in the IGEA process and EMC is following up with all the buildings on the implementation process.